

AMERICAN EAGLE FIRE PROTECTION, INC.

4711 North Dixie Highway – Boca Raton, FL 33431

Telephone: 561-750-3698 – Fax: 561-750-8496

LIC # 33490800012003

FLOW TEST

STATIC PRESSURE (psi)	RESIDUAL PRESSURE (psi)	PITOT PRESSURE (psi)	PITOT FLOW (gpm)	OUTLET SIZE
75	70	19	729	2"

Address: 911 E. Atlantic Boulevard, Pompano Beach, FL

Flow Test Date: Tuesday, August 15, 2023 9:00 a.m. – Wednesday, August 16, 2023 9:00 a.m.

Sketch of Test Location



x *Adam Summers*

Date: 8-17-2023

DRC

PZ23-12000043
02/21/2024

DRC

PZ23-12000043
11/15/2023