

1. PROVIDE ALL NEW HVAC DESIGN FOR 3 NEW WAREHOUSE BAYS
2. PROVIDE HEAT LOADS, ENERGY CALCS AND VENTILATION CALCS

Fill, Void or Cavity Material* – Caulk or Sealant – Min 5/8 in. (16 mm) thickness of caulk applied within annulus, flush with both surfaces of wall or roof. Min 1/4 in. (6 mm) diam bead of caulk applied to gypsum board/penetrate interface at point contact location on both sides of wall or roof.

(15WB+, CP 25WB+ caulk or FB-3000 WT sealant)*Bearing the UL Classification Mark. This Material was extracted and drawn by 3M Fire Protection Products from the 2008 edition of the UL Fire Resistance Directory.)

1 MECHANICAL SHEET INDEX
SCALE: NTS

MECHANICAL PLANS FOR:
1150 SW 30TH AVE.
POMPANO BEACH, FL 33069

PROJECT:
1150 SW 30TH AVE.

[illegible]
$$1/4'' = 1'$$