

PZ25- 12000016
12/03/2025

BROWARD COUNTY PUBLIC WORKS DEPARTMENT PLOTTED: 10/2024	WATER & WASTEWATER SERVICES ENGINEERING DIVISION 2505 WEST COPPIN ROAD FORTLAUDERDALE, FL 33309 PHONE NO. 954-831-0745 FAX: 954-831-0925	<h1 style="margin: 0;">STANDARD DETAIL</h1>
---	--	---

PLAN

SECTION A-A

1. SINGLE SERVICE CONNECTIONS SHALL USE 6" SDR 26 PVC PIPE AND FITTINGS.
2. SINGLE SERVICE CONNECTIONS BELOW 12' DEPTH SHALL BE C-900 PVC UNTIL LESS THAN 12 FOOT DEPTH.
3. USE RISER CONNECTIONS WHERE INVERT OF SEWER IS MORE THAN 7'-0" DEEP.
4. WHERE BELL OF WYE AND SPIGOT OF EXISTING MAIN ARE NOT COMPATIBLE, USE A SECOND FLEXIBLE COUPLING.
5. RIGID COUPLINGS MAY BE USED IN LIEU OF FLEXIBLE COUPLINGS.
6. MAINTAIN 36" MINIMUM COVER FROM TOP OF SERVICE TO FINISH GRADE; WHERE NOT TECHNICALLY FEASIBLE CONTACT WWS ENGINEERING.
7. PVC SERVICES SHALL BE INSTALLED IN ACCORDANCE WITH MINIMUM STANDARDS OF THE ULL-BELL HANDBOOK OF PVC PIPE DESIGN AND CONSTRUCTION, LATEST EDITION.

REVISED	WYE SEWER SERVICE CONNECTION	FIGURE 331
7/7/2021		