

LIGHTING PLAN
SCALE: 1"=10'

- SPECIFIC LIGHTING NOTES:**
- 1. AN ADDITIONAL LIGHT WAS ADDED FOLLOWING AND INITIAL LIGHTING STUDY.
 - 2. THE RESULT OF THE SECOND STUDY ARE PRESENTED IN THIS PLAN. THE SITE WAS DIVIDED INTO A 20' X 20' GRID AND READING WERE TAKE AT THE CORNERS OF THE GRID.
 - 3. THE STUDY REVEALS NO ADDITIONAL LIGHTING WOULD BE REQUIRED AT THE STUDIED SITE.
 - 4. NO LIGHT WAS REDUCED DUE TO SHADOWING AS THE SITE IS OPEN.
 - 5. THIS DRAWING IS A PRESENTATION OF THE EXISTING CONDITIONS OVERLAYED ON THE PROPOSED PARKING LOT.


LIGHTING CRITERIA	
AVERAGE fc	= 5.52
MAXIMUM fc	= 33.60
MINIMUM fc	= 0.70
AVERAGE/MINIMUM	= 7.89
MAXIMUM/MINIMUM	= 48.00



ADDED LIGHT FIXTURE



11390 TEMPLE STREET
COOPER CITY, FL 33830
TEL: (864) 434-6905 FAX: (864) 434-5804
CERTIFICATE OF AUTHORIZATION NUMBER 30230



PARKING LOT
NW 6TH AVENUE & NW 6TH STREET
POMPAHO BEACH, FLORIDA

REVISIONS	DATE	DESCRIPTION
No.		

GEA PROJECT NO.: 20093
DATE: 11-06-2020
SCALE: AS SHOWN
DESIGNED BY: R.B.J.
DRAWN BY: L.B.
CHECKED BY: R.B.J.
APPROVED BY: R.B.J.

SHEET TITLE
LIGHTING PLAN
LOT 12 OF 12

DRC
PZ21-12000017
5/19/21