



DESIGN
URBN Design

696 N.E. 125th Street | North Miami, FL 33161

August 30, 2022

RE: FESTIVAL MARKETPLACE – RACETRAC C2022051834

To Water and Wastewater Services:

I request that Water and Wastewater Services use its generic fire protection level of service standards for this project of 3,575 GPM at 20 PSI residual pressure in the public water supply system as indicated in Table 6 of its published Guidelines for Determining Ability to Provide Potable Water and Sanitary Sewer Service for Commercial/Retail type of structure.

Please feel free to contact me at 321-217-6247 if you have any questions.

Sincerely,

Christopher Collins, P.E.
President

DRC

PZ22-12000027

10/5/2022