



4083 S. US Highway #1, Ste 101
Rockledge, FL 32955-5308
(321) 633-4522 (w) (321) 633-4528 (f)

Comment Responses

City of Pompano Beach
Planning and Zoning
100 W Atlantic Blvd
Pompano Beach, FL 33060
954-786-4669

Date: July 6, 2021

Re: 3 Unit Townhouse Building
554 N Riverside Dr.
Pompano Beach, FL 33062
[Click or tap here to enter text.](#)

Listed below are responses to Building Department comments:

RESPONSES TO COMMENTS DATED 7/6/2021

Photometric COMMENTS

1. 16. A complete photometric plan was not provided. Identify the property line on the photometric plan and the foot-candles on the northern property line. The driveways shall have a minimum of 0.5 foot-candle and the property line shall have a maximum of 2.0 foot-candles, per 155.5401.E.

Response: See revised drawing.

Please do not hesitate to call if you have any questions or comments.

Sincerely,

David DaSilva

David A. DaSilva, PE

DDC Engineering, Inc.

DRC

PZ21-12000019

10/20/2021

Page 1 of 1
21058