



Phone: (954) 545-7016

**City of Pompano Beach
UTILITIES TREATMENT PLANT**

Fax: (954) 545-7046

MEMORANDUM NO. 18 – 08

DATE: March, 15 2018

TO: Gregory P. Harrison, City Manager

VIA: A. Randolph Brown, Utilities Director *ARB*

C: Otis Thomas, General Services Director

FROM: Phil Hyer, Utilities Treatment Plants Superintendent *PH*

SUBJECT: Contract Modification Bid L-53-16

Utilities staff requests consideration by the City Commission of a contract modification for Bid L-53-16, in the amount of \$40,805.91 and +28 days of additional contract time. This work is required due to unforeseen circumstances during the installation of flow meters at both the Water and Reuse Plants.

The Water Plant meter contractor could not get a positive shut off on a 30" valve that was needed to isolate the flowmeter from the distribution main. Work had to be aborted until this valve can be replaced.

Once construction began at the Reuse Plant, it was discovered that modifications would be needed to the existing manhole to accommodate the new flow meter.

The cost expenditure for this Contract Modification is available in CIP 05-886 account number 420 7264 533 65-11, for the amount of \$34,206.24, for the Water Plant portion of the work. For the Reuse Plant portion of work, funding is available in CIP 05-887 account number 420 7265 533 65-11, for the amount of \$6,599.67.

Please find attached:

1. Contract Modification Form and back up.