

Memo

To: Zoning Board of Appeals

From: Pete McGinnis Fire Marshal & James Galloway, Fire Inspector

Date: December 9, 2019

Re: Zoning Board of Appeal 19-15000009

Due to the fact the petitioner is able to meet all of the Fire Department requirements at this time we have no objections and approves the request for a Temporary Use Permit. However, the petitioner shall maintain all proper fire department access as per chapter 18 of NFPA 1 as amended from time to time.

*Additional comments may follow throughout the remainder of the permitting process. The building shall be in compliance with All NFPA Standards prior to receiving Fire Department approval.