



SYMBOL LEGEND	
CNTL	SECURITY ALARM CONTROL PANEL
1255	COMM. CENTER KEYPAD
1078C	DOOR CONTACT
2202AU	DOOR CONTACT
4510AU	DOOR CONTACT
G	GLASS BREAK
DS9370 (360)	STYLE MOTION
RTE	(CURTAIN) STYLE MOTION (ceiling mount)
SAFE	VIBRATION CONTACT
SIREN	WITH CEILING GRILL COVER
STROBE	
DT	DT435T MOTION

No Scale

SECURITY SYMBOL LEDGEND

1. CEILING IS OPEN BAR JOIST STEELWORK THROUGHOUT.
2. ALARM DEVICES TO BE MOUNTED TO BOTTOM OF BAR JOIST &/OR UNISTRUT.
3. USE ONLY ORANGE BA CABLE & GREY SHEILDDED CABLE IN ALL OVERHEAD CABLE RUNS.
4. USE ONLY ORANGE TY-WRAPS!
5. FRONT DOOR MAGNETS WILL BE SENTROL 1840N TYPE INSERTED TO INSIDE TOP OF DOOR WITH SILICONE FILLETS TO MAINTAIN STABILITY OF THE MAGNET - SEE DETAIL SHEET E-10, DO NOT USE MAGNETS PROVIDED WITH 1078C CONTACTS!
6. DOCK DOUBLE DOORS, IF SHOWN ON DRAWINGS, SHALL HAVE SENTROL 2202AU CONTACTS AND DETEX SOUNDER INSTALLED ON THE ACTIVE LEAF.
7. EMERGENCY EXIT DOOR SHALL HAVE SENTROL 2202AU CONTACT AND WILL SOUND BURG SIREN ANY TIME DOOR IS OPENED.
8. ROLL-UP DOOR HAS A GRI 4510AU CONTACT TO BE PLACED IN A RECESS IN THE FLOOR SLAB IN VICINITY OF THE DOOR. NOTE THIS CONTACT HAS DIFFERENT WIRE COLORS THAN ANY OF THE OTHER CONTACTS. ONCE CONTACT IS SET FILL RECESS WITH A PREMIX ACRYLIC CONCRETE PATCH LEVEL TO TOP OF SLAB.
9. ALL DOOR CONTACTS ARE NORMALLY CLOSED ONLY AND WILL BE ON SEPARATE ZONES.

No Scale

SECURITY SYSTEM NOTES

1/8" = 1'-0"

FLOOR PLAN

1. AUTOZONE WILL FURNISH ORANGE CAT 5 CABLE TO BE USED BY CONTRACTOR IN WIRING FOR CCTV.
2. EACH CAMERA LOCATION SHALL BE INDIVIDUALLY WIRED WITH A CAT 5 CABLE RUN FROM THE CAMERA LOCATION TO THE DVR LOCATION IN THE MANAGER'S OFFICE.
3. THE CABLE RUNS SHALL START AT THE BOTTOM CHORD OF THE CLOSEST BAR JOIST TO THE CAMERA BEING SERVED, PROVIDE 10 FEET OF WIRE COILED AND WIRE TIED TO THE JOIST. THEN UP THE BAR JOIST TO THE TOP CHORD AND ACROSS THE STORE TO THE CCTV POWER POLE AT THE MANAGER'S OFFICE, THEN DOWN THE INSIDE OF THE POLE TO THE FLOOR LEVEL. PROVIDE 20 FEET OF CABLE OUT THE BOTTOM OF THE POWER POLE. TAG BOTH ENDS OF THE CABLE RUN WITH THE CAMERA NUMBER BEING SERVED. SEE SHEET E-2 FOR ADDITIONAL POWER POLE INFORMATION.
4. WIRE TIE CABLE TO BAR JOIST IN A MANNER THAT COMPLIES WITH THE REQUIREMENTS OF THE LATEST EDITION OF THE NATIONAL ELECTRIC CODE, OR PROVIDE CONDUIT FOR CABLE RUNS IF REQUIRED BY LOCAL GOVERNING AUTHORITY.
5. AUTOZONE WILL INSTALL THE CAMERAS AND MAKE THE FINAL CONNECTIONS BOTH AT THE CAMERA AND AT THE DVR.

No Scale

CCTV WIRING NOTES

- MASTER ZONES
- Z1 - REAR EMERGENCY EXIT (24 HR)
 - Z2 - SALES FLOOR EMERGENCY EXIT (24 HR)
 - Z3 - MOTION DETECTOR, REAR EMER EXIT
 - Z4 - MOTION DETECTOR, SALE FLOOR EMER EXIT
 - Z5 - FRONT DOOR CONTACTS
 - Z6 - ROOF HATCH
 - Z7 - DOCK MAN DOOR
 - Z8 - DOCK OVER HEAD DOOR
 - Z9 - MOTION DETECTOR, DOCK MAN DOOR
 - Z10 - MOTION DETECTOR, DOCK OVERHEAD DOOR
 - Z11 - GLASS BREAK DETECTOR, SALES AREA
 - Z12 - MOTION DETECTOR, HARD PARTS AREA

- MASTER ZONES
- Z13 - MOTION DETECTOR, SAFE
 - Z14 - MOTION DETECTOR, REGISTERS
 - Z15 - MOTION DETECTOR, SALES AREA
 - Z16 - MOTION DETECTOR, SALES AREA
 - Z17 - MOTION DETECTOR, SALES AREA
 - Z18 - MOTION DETECTOR, SALES AREA
 - Z19 - MOTION DETECTOR, HARD PARTS AREA
 - Z20 - GLASS BREAK DETECTOR, HARD PARTS AREA
 - Z21 - TAMPER SWITCH
 - Z22 - CELL SERVICE LOSS
 - Z23 - CELL COM FAIL
 - Z24 - CELL A/C FAIL

NOTE:

NOT EVERY ZONE WILL BE FOUND IN EVERY STORE, SEE SPECIFIC PLAN FOR THE STORE'S REQUIREMENTS.

No Scale

SECURITY ZONE SCHEDULE

REVISIONS

NO.	DATE	DESCRIPTION
1		
2		
3		
4		
5		
6		

AutoZone Store No. 6365
3001 WEST ATLANTIC AVE

POMPANO BEACH, FL 33096
Public Safety Security Plan

Architect: George Callow - License #AR0014155

123 South Front Street

Memphis, Tennessee 38103

TEL: 901-495-8705 FAX: (901) 495-8969

For Bidding & Contractor Information Contact:
McGraw-Hill Construction Tel. 615-884-1017
www.construction.com

George W Callow
AR0014155
55 State of Florida
Date: 2020.02.04
10:55:06 -06'00

03/19/17

7 PER

AAC

PZ20-12000007

2/2/21

AAC

PZ20-12000007

03/03/2020