


GENERAL NOTES:


- For curb, gutter and curb & gutter provide $\frac{1}{8}$ " - $\frac{1}{4}$ " contraction joints at 10' centers (max.). Contraction joints adjacent to concrete pavement on tangents and flat curves are to match the pavement joints, with intermediate joints not to exceed 10' centers.
- Locate expansion joints for curb, gutter and curb & gutter in accordance with Specification 520.

TABLE OF CONTENTS:


Sheet	Description
1	General Notes and Contents
2	Concrete Curb and Gutter
3	Curb and Gutter Joints and Endings, Concrete Bumper Guard, and Asphaltic Concrete Curb




TYPE A



TYPE E




TYPE F




SHOULDER GUTTER

TYPE A, TYPE E, TYPE F, AND SHOULDER GUTTER
(Other Types Similar)




CONCRETE BUMPER GUARD




NOTE: For use adjacent to concrete or flexible pavement, concrete shown (See Note 4).

TYPE A



NOTE: For use adjacent to concrete or flexible pavement, concrete shown.

TYPE B




NOTE: For use adjacent to concrete or flexible pavement, concrete shown.


TYPE D

NOTES:


- For Type A, Type B, and Type D Curb: Expansion joint, preformed joint filler and joint seal are required between curbs and concrete pavement only, see Sheet 3.
- For Type E, Type F, Drop Curb, and Valley Gutter: When used on high side of roadways, match the cross slope of the gutter to the cross slope of the adjacent pavement. The thickness of the lip is 6", unless otherwise shown on Plans.
- For Type RA, rotate entire section so that gutter cross slope matches slope of adjacent circulating roadway pavement.
- For details depicting usage of Type A Curb adjacent to flexible pavement see Sheet 3.




TYPE E




TYPE F




TYPE RA




DROP CURB




TOLL HEADER CURB




VALLEY GUTTER




SECTION A-A



SECTION B-B



SECTION C-C



SHOULDER GUTTER

CONCRETE CURB AND GUTTER

LAST REVISION	REVISION	DESCRIPTION:
11/01/21		

LAST REVISION	REVISION	DESCRIPTION:
11/01/21		




LAST REVISION	REVISION	DESCRIPTION:
11/01/21		

1 CURB AND GUTTER
C5.0 NOT TO SCALE

2 CURB AND GUTTER
C5.0 NOT TO SCALE

GENERAL NOTES:

- Construct sidewalks in accordance with Specification 522. Use 6" concrete for Sidewalks and Curb Ramps Located within Curb Returns (See Plan View). Install all other concrete with thickness as shown, unless otherwise detailed in the Plans.
- Include detectable warnings on sidewalk curb ramps in accordance with Index 522-002.
- For Driveways see Index 522-003.
- Bond breaker material can be any impermeable coated or sheet membrane or preformed material having a thickness of not less than 6 mils and not more than $\frac{1}{2}$ ".
- Construct sidewalks with Edge Beam through the limits of any surface mounted Pedestrian/Bicycle Railing or Pipe Guardrail shown in the plans. (See RAILING DETAIL)




LEGEND:


4" Thick Sidewalk

6" Thick Sidewalk

Utility Strip






SAWED JOINTS




LONGITUDINAL SECTION

LEGEND:

- $\frac{1}{2}$ " Expansion Joints (Preformed Joint Filler) between the sidewalk and; driveways, sidewalk-intersections, and all other fixed objects (e.g. drainage inlets and utility poles).
- $\frac{1}{2}$ " Dummy Joints, Tooled
- $\frac{1}{2}$ " Farmed Open Joints
- $\frac{1}{2}$ " Saw Cut Joints, $1\frac{1}{2}$ " Deep (within 96 hours) Max. 5' Centers
- $\frac{1}{2}$ " Saw Cut Joints, $1\frac{1}{2}$ " Deep (within 12 hours) Max. 30' Centers (Joints) Required When Length Exceeds 30'
- $\frac{1}{2}$ " Expansion Joint When Run Of Sidewalk Exceeds 120'. Intermediate locations when called for in the plans or at locations as directed by the Engineer.
- Cold Joint With Bond Breaker, Tooled




GENERAL NOTES AND CONCRETE SIDEWALK ON CURBED ROADWAYS



ISOMETRIC VIEW

PLAN VIEW


CR-D



ISOMETRIC VIEW

PLAN VIEW


CR-E



ISOMETRIC VIEW

PLAN VIEW

CR-F



ISOMETRIC VIEW

PLAN VIEW

CR-G

SIDEWALK CURB RAMPS CR-D, CR-E, CR-F & CR-G



LAST REVISION	REVISION	DESCRIPTION:
11/01/21		

LAST REVISION	REVISION	DESCRIPTION:
11/01/21		

LAST REVISION	REVISION	DESCRIPTION:
11/01/21		

3 CONCRETE SIDEWALK
C5.0 NOT TO SCALE

4 SIDEWALK CURB AND RAMPS
C5.0 NOT TO SCALE



5200 Buffington Rd.
Atlanta Georgia,
30349-2998

Bowman

Certificate of Authorization License No. 30462
610 SE 7th St, Suite 300
Fort Lauderdale, FL 33316
Phone: (954) 314-6461
www.bowman.com
© 2021 Bowman Consulting Group Ltd

Seal

This item has been
digitally signed and
sealed by Andres
Mizrahi, P.E.
on the date
adjacent to this
seal

Printed copies
of this document
are not considered
signed and sealed
and the signature
must be verified on any
electronic copy
2023.05.30 13:54:12-0400
ANDRES MIZRAHI, P.E.
FLORIDA REG. NO. 92421
(FOR THE FIRM)

CHICK-FIL-A
POMPANO BEACH
2250 NORTH FEDERAL HIGHWAY
POMPANO BEACH, FL 33062

FSU# 2483

REVISION SCHEDULE	DESCRIPTION
NO. DATE	PAVEMENT ST & SIDEWALK SPECS
1 3/9/22	REVISED INLET RIM EL.
2 7/19/22	REVISED MENU ISLAND & STRIPING
3 9/21/22	REVISED ORDER CANOPY
4 10/6/22	EXFILTRATION TRENCH
5 10/26/22	ADA RAMP GRADING
6 12/08/22	PARKING ISLAND GRADING
7 12/13/22	SIDEWALK REVISION

CURRENT DESIGN	2021-005
NOTE APPLIED	
PROJECT #	010014-01-138
PRINTED FOR	PERMIT
DATE	5/24/2023
DRAWN BY	ST

FOR PERMIT
PZ23-1200022
07/19/2023