

Fire Prevention

- 1- Show location of FDC for fire sprinkler system. Must maintain minimum 3ft clearance on each side and rear with a 6ft clear width in front to public right of way. Cannot be located behind other backflows and meters or landscaping.

Response: Refer to civil sheet C-4 Water and Sewer Connection Plan for FDC location.

Engineering

- 1- Submit/upload the (BCEPMGD) Broward County Environmental Protection and Growth Management Division Surface Water Management permit or exemption for the proposed paving and drainage shown on the civil engineering drawings.

Response: See approved permit attached.

- 2- Submit / upload a sediment and erosion control plan for the subject project. All site development must be performed by using Best Management Practices.

Response: Sediment and erosion control plan has been submitted as part of civil sheet C-2.

- 3- Prior to the approval of the City Engineering Division, the City's Planning and Zoning Division must approve these plans.

Response: Acknowledged

- 4- Prior to the approval of the City Engineering Division, the City's Utilities Division must approve these plans.

Response: Acknowledged

- 5- Submit / upload the 2022 City Engineering standard details for the proposed off-site water, sewer connections, road restoration, paving, curbing and sidewalks. These detail drawing may be obtained in pdf format from the City's website.

Response: Refer to sheet C-5.1, C-5.2 and C-5.3 Construction Details for applicable 2022 City Engineering standard details.