

# AMERICAN EAGLE FIRE PROTECTION, INC.

4711 North Dixie Highway – Boca Raton, FL 33431

Telephone: 561-750-3698 – Fax: 561-750-8496

LIC # 33490800012003


## FLOW TEST B

STATIC PRESSURE (psi)	RESIDUAL PRESSURE (psi)	PITOT PRESSURE (psi)	PITOT FLOW (gpm)	OUTLET SIZE
80	78	38	1016	2"

**Address:** 2400 E. Atlantic Boulevard, Pompano Beach

**Flow Test Date:** Wednesday, January 22<sup>nd</sup> 2025 at 8:30a.m. – Thursday, January 23<sup>rd</sup>, 2025 at 8:30 a.m.

### Sketch of Test Location



X *Dario Cimetta*

American Eagle Technician

*1-23-25*

Date

**DRC**

PZ25-12000001

04/02/2025