

AMERICAN EAGLE FIRE PROTECTION, INC.

4711 North Dixie Highway – Boca Raton, FL 33431

Telephone: 561-750-3698 – Fax: 561-750-8496

LIC # 33490800012003

FLOW TEST

STATIC PRESSURE (psi)	RESIDUAL PRESSURE (psi)	PITOT PRESSURE (psi)	PITOT FLOW (gpm)	OUTLET SIZE
78	72	60	1298	2.5"

Address: 601 N. Federal Highway, Pompano Beach, FL

Flow Test Date: October 19, 2022-October 20, 2022

Sketch of Test Location

