


IRRIGATION SCHEDULE HOUSE MODEL B				
SYMBOL	MANUFACTURER/MODEL/DESCRIPTION	QTY	PSI	DETAIL
	Rain Bird 1806-PRS ADJ Turf Spray 6.0" Pop-Up Sprinkler with Co-Molded Wiper Seal. Side and Bottom Inlet. 1/2" NPT Female Threaded Inlet. Pressure Regulating.	28	30	
	Rain Bird 1806-PRS ADJ Turf Spray 6.0" Pop-Up Sprinkler with Co-Molded Wiper Seal. Side and Bottom Inlet. 1/2" NPT Female Threaded Inlet. Pressure Regulating.	24	30	
	Rain Bird 1800-PA-8S-PRS ADJ Shrub Spray on fixed riser with the PA-8S-PRS Pressure Regulating Shrub Adapter. Use with 1/2" MPT threaded risers.	12	30	
	Rain Bird 1800-5 Series Stream Stream Bubbler on fixed riser.	12	15	
SYMBOL	MANUFACTURER/MODEL/DESCRIPTION	QTY		DETAIL
	Rain Bird PESB-PRS-D (2) 1" 1in., 1-1/2in., 2in. Plastic Industrial Valves. Low Flow Operating Capability, Globe Configuration. With Pressure Regulating Module, and Scrubber Technology for Reliable Performance in Dirty Water Irrigation Applications.	6		
	Febco 825Y 1" Reduced Pressure Backflow Preventer	1		
	Rain Bird ESP4MEi with (1) ESP-SM6 10 Station, Hybrid Modular Indoor Controller. For Residential or Light Commercial Applications.	1		
	Rain Bird RSD-BEx (2) Rain Sensor, with metal latching bracket, extension wire.	1		
	Water Meter 5/8" 5/8" METER	1		
	Irrigation Lateral Line: PVC Schedule 40 1/2"	86.59 l.f.		
	Irrigation Lateral Line: PVC Schedule 40 3/8"	200.8 l.f.		
	Irrigation Lateral Line: PVC Schedule 40 3/4"	200.3 l.f.		
	Irrigation Lateral Line: PVC Schedule 40 1 1/4"	452.0 l.f.		
	Irrigation Lateral Line: PVC Schedule 40 1 1/2"	200.1 l.f.		
	Irrigation Mainline: PVC Schedule 40-NP 3/4"	103.5 l.f.		
	Irrigation Mainline: PVC Schedule 40-NP 1"	128.2 l.f.		
	Irrigation Mainline: PVC Schedule 40-NP 1 1/4"	24.3 l.f.		
	Pipe Sleeve: PVC Schedule 40	11.9 l.f.		



CRITICAL ANALYSIS

Generated: 2025-01-12 01:54

P.O.C. NUMBER: 01
Water Source Information: 5/8" METER


FLOW AVAILABLE
Water Meter Size: 5/8"
Flow Available: 15 GPM

PRESSURE AVAILABLE
Static Pressure at POC: 60 PSI
Elevation Change: 5.00 ft
Service Line Size: 1"
Length of Service Line: 20 ft
Pressure Available: 57 PSI


DESIGN ANALYSIS
Maximum Station Flow: 14.47 GPM
Flow Available at POC: 15 GPM
Residual Flow Available: 0.53 GPM

Critical Station: 2
Design Pressure: 30 PSI
Friction Loss: 1.14 PSI
Fittings Loss: 0.11 PSI
Elevation Loss: 0 PSI
Loss through Valve: 2.28 PSI
Pressure Req. at Critical Station: 33.5 PSI
Loss for Fittings: 0 PSI
Loss for Main Line: 3.13 PSI
Loss for POC to Valve Elevation: 0 PSI
Loss for Backflow: 11.5 PSI
Loss for Water Meter: 7.63 PSI
Critical Station Pressure at POC: 55.8 PSI
Pressure Available: 57 PSI
Residual Pressure Available: 1.19 PSI

SLEEVING SCHEDULE	
PIPE SIZE	SLEEVING PIPE SIZE
3/4"	2"
1"	2"
1-1/4"	3"
1-1/2"	3"
2"	4"
3"	6"
4"	8"
6"	12"
8"	16"



FOLIAGE EXPRESSIONS
8801 SW 192nd Terrace,
Cutler Bay, FL 33157



PROPOSED 12 HOUSES
NW 10TH STREET
POMPANO BEACH, FL 33060

DISTRIBUTION:	DATE:
PERMIT COMMENTS	03-22-24
PERMIT COMMENTS	03-22-24
PERMIT COMMENTS	01-14-25

DRAWING NAME:
HOUSE MODEL B
AT N.W. 11TH. STREET
IRRIGATION PLAN
AND SCHEDULE

DRAWING NUMBER:
L-302.1