



Hydraulic Calculations by HydraCALC

SUMMERS FIRE SPRINKLERS, INC
751 PARK OF COMMERCE DR, #100
BOCA RATON, FL 33487
MICHELLE MEISEL, P.E. #45316
561-393-6718

Job Name : Bldg#1 UNIT A Fire Plans-cALAC
Drawing : BLDG 1
Location : 117 SOUTH RIVERSIDE DRIVE, POMPAÑO BEACH FL
Remote Area : UNIT B
Contract : BC922
Data File : Bldg#1 UNIT A Fire Plans-cALAC Area 2.WXF

DRC

HYDRAULIC DESIGN INFORMATION SHEET

Name - RIVERSIDE TOWNHOUSE Date - 10/23/21
Location - 117 SOUTH RIVERSIDE DRIVE, POMPAN0 BEACH FL
Building - BLDG 1 System No. - UNIT B
Contractor - SUMMERS FIRE SPRINKLERS, INC Contract No. - BC922
Calculated By - CD Drawing No. - FP-2
Construction: () Combustible () Non-Combustible Ceiling Height
OCCUPANCY - 13R

S Type of Calculation: (X)NFPA 13 Residential ()NFPA 13R (X)NFPA 13D
Y Number of Sprinklers Flowing: ()1 (X)2 ()4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - Gpm System Type
Listed Pres. at Start Point - Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 16 x 16 () Deluge () PreAction
E Domestic Flow Added - Gpm Sprinkler or Nozzle
S Additional Flow Added - Gpm Make TYCO Model TY3596
I Elevation at Highest Outlet - Feet Size 1/2" K-Factor 4.9
G Note: Temperature Rating 155
N

Calculation Gpm Required 3098 Psi Required 66.69 At Test
Summary C-Factor Used: Overhead 150 Underground 140

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 10/22/21 Rated Cap. Cap.
T Time of Test - 9:15 AM @ Psi Elev.
E Static (Psi) - 80 Elev.
R Residual (Psi) - 77 Other Well
Flow (Gpm) - 1306 Proof Flow Gpm
S Elevation - 2.5

P Location:

P
L Source of Information:
Y

DRC

Water Supply Curve

SUMMERS FIRE SPRINKLERS, INC
Bldg#1 UNIT A Fire Plans-cALAC


Page 2
Date

City Water Supply:

C1 - Static Pressure : 80
C2 - Residual Pressure: 77
C2 - Residual Flow : 1306

Demand:

D1 - Elevation : 14.617
D2 - System Flow : 25.987
D2 - System Pressure : 66.696
Hose (Demand) : 5
D3 - System Demand : 30.987
Safety Margin : 13.301



Fittings Used Summary

SUMMERS FIRE SPRINKLERS, INC
Bldg#1 UNIT A Fire Plans-cALAC

Fitting Legend																					
Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zaa	Ames 2000B	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

SUMMERS FIRE SPRINKLERS, INC
Bldg#1 UNIT A Fire Plans-cALAC

Page 4
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DP01	35.25	4.9	7.0	na	12.96	0.05	94	7.0
EQ01	36.25		6.71	na				
DP02	35.25	4.9	7.0	na	12.96	0.05	210	7.0
EQ02	36.25		6.71	na				
S4	36.25	K = K @ EQ01	6.71	na	12.96			
B13	36.25		6.89	na				
B12	36.25		7.09	na				
B11	36.25		7.52	na				
B10	36.25		8.59	na				
B9	36.25		8.67	na				
B8	36.25		10.51	na				
B7	25.0		16.63	na				
B6	25.0		17.59	na				
B5	25.0		18.12	na				
B4	13.0		24.64	na				
B3	13.0		26.4	na				
B2	13.0		27.63	na				
B1	13.0		29.49	na				
1	13.0		32.98	na				
2	-2.0		46.02	na				
U11	-2.0		47.2	na				
U10	-2.0		62.08	na				
U9	-2.0		66.33	na				
U8	-2.0		67.48	na				
U2	-2.0		68.64	na				
TEST	2.5		66.7	na	5.0			
S3	36.25	K = K @ EQ02	6.77	na	13.02			

The maximum velocity is 8.82 and it occurs in the pipe between nodes B1 and 1

DRC

Final Calculations : Hazen-Williams

SUMMERS FIRE SPRINKLERS, INC
Bldg#1 UNIT A Fire Plans-cALAC

Page 5
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
DP01 to EQ01	35.25 36.25	4.90	12.96 12.96	1 1.101	E 3.825	1.000 3.825 4.825	150 0.0305	7.000 -0.433 0.147		Vel = 4.37	
EQ01			0.0 12.96					6.714		K Factor = 5.00	
DP02 to EQ02	35.25 36.25	4.90	12.96 12.96	1 1.101	E 3.825	1.000 3.825 4.825	150 0.0305	7.000 -0.433 0.147		Vel = 4.37	
EQ02			0.0 12.96					6.714		K Factor = 5.00	
S4 to B13	36.25 36.25	5.0	12.96 12.96	1 1.101		5.830 5.830	150 0.0305	6.714 0.0 0.178		K = K @ EQ01 Vel = 4.37	
B13 to B12	36.25 36.25		0.0 12.96	1 1.101	E 3.825	2.740 3.825 6.565	150 0.0305	6.892 0.0 0.200		Vel = 4.37	
B12 to B11	36.25 36.25		13.03 25.99	1 1.101		3.880 3.880	150 0.1106	7.092 0.0 0.429		Vel = 8.76	
B11 to B10	36.25 36.25		0.0 25.99	1 1.101		9.700 9.700	150 0.1104	7.521 0.0 1.071		Vel = 8.76	
B10 to B9	36.25 36.25		0.0 25.99	1 1.101		0.720 0.720	150 0.1111	8.592 0.0 0.080		Vel = 8.76	
B9 to B8	36.25 36.25		0.0 25.99	1 1.101	T E 3.825	3.300 13.387 16.687	150 0.1104	8.672 0.0 1.843		Vel = 8.76	
B8 to B7	36.25 25		0.0 25.99	1 1.101		11.250 11.250	150 0.1105	10.515 4.872 1.243		Vel = 8.76	
B7 to B6	25 25		0.0 25.99	1 1.101	2E 7.65	1.000 7.650 8.650	150 0.1104	16.630 0.0 0.955		Vel = 8.76	
B6 to B5	25 25		0.0 25.99	1 1.101	E 3.825	1.000 3.825 4.825	150 0.1105	17.585 0.0 0.533		Vel = 8.76	
B5 to B4	25 13		0.0 25.99	1 1.101		12.000 12.000	150 0.1105	18.118 5.197 1.326		Vel = 8.76	
B4 to B3	13 13		0.0 25.99	1 1.101	E T 9.563	2.500 13.387 15.887	150 0.1104	24.641 0.0 1.754		Vel = 8.76	
B3 to B2	13 13		0.0 25.99	1 1.101		7.380 7.380	120 0.1669	26.395 0.0 1.232		Vel = 8.76	
B2 to B1	13 13		0.0 25.99	1 1.101	E 3.825	13.060 3.825 16.885	150 0.1105	27.627 0.0 1.865		Vel = 8.76	

DRC

Final Calculations : Hazen-Williams

SUMMERS FIRE SPRINKLERS, INC
Bldg#1 UNIT A Fire Plans-cALAC

Page 6
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
B1 to 1	13 13		0.0 25.99	1 1.097	2E Zaa	4.974 20.504	120 0.1699	29.492 0.0 3.483		Vel = 8.82	
1 to 2	13 -2		0.0 25.99	1 1.097	Zaa	0.0 15.000	120 0.1699	32.975 10.496 2.549		** Fixed Loss = 4 Vel = 8.82	
2 to U11	-2 -2		0.0 25.99	1 1.097	2E	4.974 1.970 4.974 6.944	120 0.1698	46.020 0.0 1.179		Vel = 8.82	
U11 to U10	-2 -2		0.0 25.99	1 1.097	3E	9.923 9.923 116.493	140 0.1277	47.199 0.0 14.880		Vel = 8.82	
U10 to U9	-2 -2		0.0 25.99	1 1.097		1.980 1.980	140 0.1278	62.079 4.000 0.253		** Fixed Loss = 4 Vel = 8.82	
U9 to U8	-2 -2		0.0 25.99	1 1.097	T	8.269 0.700 8.269 8.969	140 0.1278	66.332 0.0 1.146		Vel = 8.82	
U8 to U2	-2 -2		0.0 25.99	1 1.097	T	8.269 0.830 8.269 9.099	140 0.1277	67.478 0.0 1.162		Vel = 8.82	
U2 to TEST	-2 2.500		0.0 25.99	4 4.1		26.620 26.620	140 0.0002	68.640 -1.949 0.005		Vel = 0.63	
TEST			5.00 30.99					66.696		Qa = 5.00 K Factor = 3.79	
S3 to B12	36.25 36.25	5.0	13.02 13.02	1 1.101	T	6.328 0.500 6.328 6.828	120 0.0464	6.775 0.0 0.317		K = K @ EQ02 Vel = 4.39	
B12			0.0 13.02					7.092		K Factor = 4.89	

DRC