

***LLR Architects Inc.***

January 3, 2024

The following recommendations were developed during the Crime Prevention Through Environmental Design review of the blueprints for our proposed warehouse development.

**CPTED Strategies.**

1. We have provided 6' high fencing around building creating clear border definition may as well as signage and proposed shrubs.
2. External Lighting:
  - a. Parking lots & pedestrian walkways and building entryways have "adequate" levels of illumination based on the following recommendations from The American Crime Prevention Institute.
    - i. Parking Lots 3-5 foot candles
    - ii. Walking surfaces 3 foot candles
    - iii. Building Entryways 5 foot candles
  - b. Exterior lighting will be controlled by automatic devices (preferably by photocell).
  - c. Exterior lighting fixture lenses should be fabricated from polycarbonate, break-resistant materials.
  - d. Plant materials, particularly tree foliage, should not interfere with or obscure exterior lighting.
3. Landscaping:
  - a. All landscaping will be trimmed and well maintained.
  - b. Landscaping will not obstruct the natural surveillance (visibility) of the area.
  - c. Plant height appropriate shrubbery along walkways to not obstruct visibility or allow individuals to hide behind.
  - d. Plants/Shrubbery should not be more than 2ft in height.
  - e. Tree canopies should not be lower than 6ft in height.
4. Buildings Perimeter Doors:
  - a. Exterior doors not used as designated entry points, should be locked to prevent entry from the exterior.
  - b. exterior doors should be equipped with electronic propped door alarms, which annunciate either locally and/or at the security office.

***LLR Architects Inc.***

9000 Sheridan Street-Suite 158  
Pembroke Pines, FL 33024

(work) 954-862-2248  
e-mail: llarosa@llarosaarchitects.com

***LLR Architects Inc.***

5. Internal Circulation and Control:
  - a. Corridors are not recessed to prevent hiding or loitering.
  - b. Trash & Recycle enclosure should be locked when not in use.
  - c. Roof access should remain locked when not in use.
6. General locations:
  - a. Mechanical, electrical, HVAC, or other equipment located outside the building should be surrounded by a protective enclosure. Ex. Dumpster enclosures.
7. CCTV:
  - a. Cameras will be provided on all 4 corners the building, along entry corridor and rear vehicular area and dumpster.
8. Fencing:
  - a. (Chain Link) fencing provides for natural surveillance within and onto the property. Ex. Parking lot and to establish a defined border definition of the entire property.
9. Signage
  - a. Proper signage will be posted throughout property.