

**HYDRANT FLOW TEST REPORT**

BLACK FIRE PROTECTION
11093 MERIDIAN DRIVE NORTH
PARKLAND, FL 33076

PHONE #: 954-741-4548

FAX #: 954-999-5258

EMAIL@BLACKFIREPROTECTION.COM

WWW.BLACKFIREPROTECTION.COM

BILL TO:	PROPERTY OUTLAWS, LLC	BLDG. INSPECTED:	2721 NE 14TH ST CAUSEWAY
STREET ADDRESS:	1201 N FEDERAL HWY #4345	BLDG. ADDRESS:	2721 NE 14TH ST CAUSEWAY
CITY, STATE & ZIP:	FORT LAUDERDALE, FL 33304	CITY, STATE & ZIP:	POMPANO BEACH, FL 33062
POINT OF CONTACT:	ROB YAKKEY	POINT OF CONTACT:	ROB YAKKEY
PHONE NUMBER:	516-519-9999	PHONE NUMBER:	516-519-9999
FAX NUMBER:	-	FAX NUMBER:	-
EMAIL ADDRESS:	propertyoutlawslc@yahoo.com	EMAIL ADDRESS:	admin@propertyoutlawslc.com
JOB NUMBER:	IM21-674	TESTER'S NAME:	Paul Meighan
CONTRACTOR LIC. #:	FPC11-000068		

HYDRANT LOCATION:	2721 NE 14th St. Causeway	HYDRANT MAKE:	Clow
NUMBER OF HYDRANTS:	2	HYDRANT MODEL:	9966

WATER SUPPLIED BY:	City of Pompano Beach	PURPOSE OF TEST:	
--------------------	-----------------------	------------------	--

FLOW HYDRANT	#1	#2	#3
Size opening	1 3/4" Hose Monster		
Pitot reading	40 psi		
GPM	694		

STATIC READING:	74	RESIDUAL READING:	68
-----------------	----	-------------------	----


RESULTS: Flow hydrant provided 694 gpm at 40 psi.

REMARKS

C. INSPECTION AND SUGGESTED IMPROVEMENTS WERE DISCUSSED WITH THE UNDERSIGNED

X	ROB YAKKEY	X		X	1/6/2022
	OWNER OR OWNER'S REPRESENTATIVE (PRINT)		AUTHORIZED SIGNATURE		DATE

D. I CERTIFY THAT THE INFORMATION ON THIS FORM IS CORRECT AT THE TIME AND PLACE OF MY INSPECTION AND THAT ALL EQUIPMENT TESTED AT THIS TIME WAS LEFT IN OPERATIONAL CONDITION UPON COMPLETION OF THIS INSPECTION EXCEPT AT NOTED ABOVE IN COMMENTS.

X	PAUL MEIGHAN	X		X	1/6/2022
	INSPECTOR (PRINT)		SIGNATURE		DATE

AAC

PZ21-12000034
6/7/2022