



Calculation Summary (Footcandles calculated using predicted lumen values @ 50K hrs of operation)						
Label	Units	Avg	Max	Min	Avg/Min	Max/Min
Paved area	Fc	2.03	6.1	0.4	5.08	15.25
Property Line	Fc	0.79	2.5	0.0	N.A.	N.A.

KEY:



EXISTING WALL MOUNTED LIGHTING FIXTURE



EXISTING LIGHT POLE

REVISIONS:	
A	ISSUED FOR REVIEW AS PER 11/24/20

Paul O. P.E. 64898
Digitally signed by Paul O. P.E. 64898
Date: 2020.12.01 10:05:47
Approved

NUTEK Engineering, LLC
421 S. FEDERAL HWY Phone (954) 670-9210
DANIA BEACH FLORIDA 33004

THE NEW AUTO TOY STORE
929 S.W. 8TH STREET
POMPA NO BEACH FLORIDA

DRAWN: J.P.D.
DATE: 11-24-20
PROJECT NUMBER:
SHEET NUMBER: