

DESIGNED	DRAWN	CHECKED
NH	NH	JY

**EGRESS LEGEND**

- 105'-6" TRAVEL DISTANCE  
EGRESS PATH OF TRAVEL
- LED EXIT SIGN WITH BATTERY PACK, WALL MOUNT  
LED EXIT SIGN WITH BATTERY PACK, CEILING MOUNT  
EXIT SIGN DIRECTIONAL ARROWS  
EXIT SIGN LIGHT DIRECTION

FEC  
SURFACE MOUNTED TYPE ABC FIRE EXTINGUISHER & CABINET. EXTINGUISHERS SHALL BE CURRENTLY DATED AND TAGGED BY LICENSED FIRE EQUIPMENT COMPANY, AND LOCATED NOT FURTHER THAN 75 FEET OF TRAVEL DISTANCE TO AN EXTINGUISHER

FE  
SURFACE MOUNTED TYPE ABC FIRE EXTINGUISHER INSTALLED ON SUPPLIED BRACKET. EXTINGUISHERS SHALL BE CURRENTLY DATED AND TAGGED BY LICENSED FIRE EQUIPMENT COMPANY, AND LOCATED NOT FURTHER THAN 75 FEET OF TRAVEL DISTANCE TO AN EXTINGUISHER

**EGRESS NOTES**

- COORDINATE FIRE ALARM DEVICES AND PANELS WITH ELECTRICAL DRAWINGS
- REFER TO FIRE PROTECTION DRAWINGS FOR SPRINKLER HEAD LOCATIONS
- REFER TO ELECTRICAL DRAWINGS FOR FIRE ALARM DEVICE LOCATIONS
- REFER TO ELECTRICAL DRAWINGS FOR EMERGENCY LIGHT LOCATIONS
- ORDINARY HAZARD OF CONTENTS (NFPA 38.1.5.1)
- A FACTOR OF 0.2 INCHES OF WIDTH PER OCCUPANT HAS BEEN USED TO CALCULATE MINIMUM DOOR AND CORRIDOR EGRESS CAPACITY
- A FACTOR OF .3 INCHES OF WIDTH PER OCCUPANT HAS BEEN USED TO CALCULATE MINIMUM CLEAR WIDTH OF STAIRWAY EGRESS CAPACITY

AUTOMATIC EXTERNAL DEFIBRILLATORS (AED) AND STOP THE BLEED KITS (SBK) SHALL BE INSTALLED AS DEFINED IN NFPA 101, LIFE SAFETY CODE, ON EVERY OTHER FLOOR BEGINNING ON THE FIRST FLOOR. THE AED AND SBK SHALL BE PLACED NEAR THE ELEVATOR(S) BEGINNING IN THE FIRST-FLOOR LOBBY (FIRST FLOOR, THIRD FLOOR, FIFTH FLOOR, ETC.)  
REFER TO BROWARD FIRE CODE AMENDMENTS SECTION F-121 FOR ADDITIONAL INFORMATION FOR LOCATION, MOUNTING, INVENTORY, TRAINING, AND INSPECTION OF REQUIRED EQUIPMENT.

IMPACT RESISTANT CLEAR GLAZING, TYP

7'-0" HIGH, IMPACT RESISTANT CLEAR GLAZING GUARDRAIL.


1 LEVEL 18 - BALLROOM FLOORPLAN  
Scale: 3/32" = 1'-0"

**R E V I S I O N S**

DATE: 9.27.2023  
COMM: 23008

**POMPANO HOTEL**

101 S. OCEAN BLVD  
POMPANO BEACH, FL 33062



Digitally signed  
by Jiro Yates  
Date:  
2023.09.29  
11:46:12-04'00'

MEETING ROOM LEVEL

HOUSE

AR-107

PZ23-12000042

11/01/2023

**DRC**