

## Current Project - Department Review Status

PZ21-12000001

Rev Cycle	Group Name	Reviewer Name	Assigned By	Review Status	Review Comments
1					
2					
	WASTE MANAGEMENT	Beth Dubow beth.dubow@copbfl.com	pamela.mccleod@copbfl.com	AuthorizedWithConditions	<p>Solid Waste and Recycling Comments  Project Name: Medical Office and Senior Center  Address: 101 NW 12th Street  P&amp;Z#: 21-12000001  Site Plan Review: 04/28/2021  DRC Meeting Date: 05/19/2021  REVIEW COMPLETED; PENDING DEVELOPMENT ORDER</p> <p>1. Although there are no objections to this site plan, please provide a sketch of the turning radii showing a garbage truck can safely enter, service and exit the site. <b>Turning radii on the site are shown on C5.0 Life Safety Plan</b></p> <p>NOTE: Owners of this commercial property are responsible for securing garbage collection service directly from Waste Management, Inc.</p> <p>NOTE: Recycling collection is not required, but it is encouraged. Recycling collection service may be obtained from a recovered materials hauler.</p> <p>NOTE: As stated in the Pompano Beach Code of Ordinances, Chapter 96, including Section 96.12(D)(1), all construction and demolition debris removal is the responsibility of the owner. All solid waste generated within the geographic boundaries of Pompano Beach shall be collected by the franchise collector (Waste Management at the time of this writing) and disposed of as directed by the city disposal agreement. All materials shall be generated from the property on which the materials are placed for removal. Information regarding container size and hauling costs may be found in Chapter 96, Section 96.13.</p> <p>NOTE: Additional comments may be necessary based upon revisions, additional plans and/or documents. Contact Beth Dubow</p>

**AAC**

PZ21-12000001

07/06/21

## Current Project - Department Review Status

					at 954-545-7047 or beth.dubow@copbfl.com should you have any questions or concerns regarding this review. <b>Acknowledged</b>
	ENGINEERING DEPARTMENT	David McGirr david.mcgirr@copbfl.com	pamela.mccleod@copbfl.com	AuthorizedWithConditions	<p>4-27-21 Medical Office and Senior Center 101 NW 12 St.</p> <p>1. Broward County EPD Surface Water Management Division permit or exemption for paving and drainage plans. <b>Acknowledged</b></p> <p>2. Submit an engineering permit application for the proposed off-site water and sewer, on/off-site asphalt paving, concrete curbing and public sidewalk. (At time of Permitting) <b>Acknowledged</b></p> <p>3. Submit a copy of a contract or schedule of values for the project scope of work listed in comment number 2. (At time of permitting) <b>Acknowledged</b></p> <p>4. Place note on landscape plans as per City Ordinance(s) §50.02(A) (4) and §100.35(E), that landscaping materials other than sod are not allowed within (5'") five feet of any portion of City owned utilities within the public street right-of-way including meters, hydrants, service lines etc. Also, please note that no trees, shrubbery or obstruction shall be placed within a 3' radius of a City-owned sewer lateral cleanout or water &amp;/or reuse meter. Show the location of all existing City owned and maintained potable water mains and services, sanitary sewer mains or laterals and storm drainage lines on the proposed landscape plans. Contact the Engineering Div. for Utility information. Engineering Standard street tree detail 316-1 <b>Note on L-1.</b></p> <p>5. The proposed watermain and services, sanitary sewer connection to service this project and proposed drainage must be approved by the City of Pompano Beach Utilities Division. <b>Acknowledged</b></p> <p>9. Please note on civil plan WS-1 Water &amp; Sewer Connection, that any existing water and/or sewer connection to the subject lots not utilized must be cut and capped at the water main if a water service and cut out and sewer if a sewer lateral.</p>

**AAC**

PZ21-12000001  
07/06/21

## Current Project - Department Review Status

					<p>How to retire old laterals</p> <ul style="list-style-type: none"> <li>• If the existing main is clay pipe and has a CIPP liner currently installed. (Install a sectional liner in the main over the old lateral thus eliminating the lateral)</li> <li>• If the existing main is clay pipe. (Dig down cut old clay pipe, sleeve back in with PVC and city approved couplings)</li> <li>• If the existing main is clay pipe and you are required to retire multiple laterals for a project. (It may be cheaper for the contractor to install a city approved CIPP liner from manhole to manhole and not cut out the laterals that they are retiring)</li> <li>• If the existing main is PVC pipe. (Remove the lateral pipe from the PVC Wye fitting and install a plug into the Wye. Install a green locating marking ball at the lateral locating, no deeper than 4 ft. below grade) <b>Note added to C4.0</b></li> </ul> <p><b>Water &amp; Sewer Plan</b></p> <p>10. Please place a note on the PGD plans that the existing roadway within the project limits and possible beyond will be inspected by the City Engineer, Public works director or a designated representative for damage due to construction prior to final acceptance. A partial or full milling and overlay of the roadways may be required. <b>Note added to 3.0 Paving, Grading and Drainage Plan</b></p> <p>**** Please note - additional review comments may be issued by the City Engineering Division throughout the remainder of the permitting process while the civil engineering plans are being finalized for this project. ****</p>
	BSO	Scott Longo scott_longo@sheriff.org	pamela.mccleod@copbfl.com	AuthorizedWithConditions	<p>Disclaimer: The services of an independent, experienced, qualified and certified Security Crime Prevention/ CPTED Consultant are highly recommended for objective and credible security review integrity.</p> <p>This review does not guarantee a crime will never occur; it is an effort to mitigate opportunities for crime and to help avoid any present and future security deficiencies,</p>

## Current Project - Department Review Status

					<p>conflicts, or liabilities that might occur without any review.</p> <p>Parking Lot, and Adjacent Access Perimeters:</p> <p>a. Parking garages and lots have one of the highest crime rates therefore the following facts must be thoroughly acknowledged and addressed:</p> <p>b. Vehicles have been burglarized in parking lots leading to significant property loss and the theft of personal identification which has resulted in identity theft fraud, therefore no security surveillance camera coverage gaps can exist (see Electronic Surveillance Section). Full coverage of surveillance cameras shown on CPTED Plan</p> <p>c. Violent Robbery incidents, primarily in parking lots, have resulted in serious personal injuries and death to both residents, guests, customers and employees, therefore no security surveillance camera coverage gaps can exist. Full coverage of surveillance cameras shown on CPTED Plan</p> <p>d. Ensure comprehensive parking lot area surveillance camera coverage/ capture Full coverage of surveillance cameras shown on CPTED Plan</p> <p>e. . Show overlapping sight “cones Full coverage of surveillance cameras shown on CPTED Plan</p> <p>CPTED Landscaping Standards</p> <p>a. Ensure to design out all landscaping and lighting conflicts to avoid existing or future obstructions to Natural or Electronic Surveillance. Trees and lighting in parking area are at different heights to avoid conflicts.</p> <p>b. Ensure to design out existing or potential concealment/ ambush points to deter/ prevent criminal activity. Site is secured with perimeter fencing and no ambush points occur outside the fence.</p> <p>c. Maintain 2' to 2.5' foot maximum height for all hedges, bushes, low plants, and ground cover. Shrubs will be maintained at required heights as noted on CPTED plan.</p>
--	--	--	--	--	--

## Current Project - Department Review Status

					<p>d. Maintain an 8" foot clear trunk without any obstructive limbs or foliage hanging down for canopy trees and tall plants that obstruct Natural &amp;/ or Electronic Surveillance. <b>Trees will be maintained at required heights as noted on CPTED plan.</b></p> <p>e. Note that young immature trees with 6" inch or less diameter trunks are excluded from this condition per code. <b>Noted</b></p>
	UTILITIES	Nathaniel Watson nathaniel.watson@copbfl.com	pamela.mccleod@copbfl.com	AuthorizedWithConditions	<p>5-10-2021</p> <p>1. Please note that additional comments may be forth coming contingent upon future submittals to the PAM and/or DRC review process. <b>Noted</b></p> <p>2. Please procure an approved Broward County EPD Surface Water Management permit or exemption for the proposed site work. Official E-Plan Submittal. <b>Acknowledged</b></p> <p>3. Please exercise best management practices with regard to protection of existing and proposed storm water systems. <b>Acknowledged</b></p>
	LANDSCAPE REVIEW	Wade Collum wade.collum@copbfl.com	pamela.mccleod@copbfl.com	Authorized	
	FIRE DEPARTMENT	Jim Galloway jim.galloway@copbfl.com	pamela.mccleod@copbfl.com	AuthorizedWithConditions	<p>4/26/21</p> <p>This P&amp;Z application is able to meet all of the Fire Department requirements at this time for Site Plan Review. However, the petitioner shall maintain all proper fire department access and water supply requirements as per chapter 18 of NFPA 1 as amended from time to time.</p> <p>*Additional comments may follow throughout the remainder of the permitting process. The buildings shall be in compliance with All NFPA Standards prior to receiving Fire Department approval.</p> <p><b>Acknowledged</b></p>
	CRA	Kimberly Vazquez kimberly.vazquez@copbfl.com	pamela.mccleod@copbfl.com	AuthorizedWithConditions	<p>1) The Land use for this parcel is C (Commercial), the zoning is B-3 (General Business).</p> <p>2) There is substantial evidence provided that the development is in line with the approved Transportation Corridor Study.</p> <p>3) The conditions of the development order &amp;</p>

**AAC**  
PZ21-1200001

07/06/21

## Current Project - Department Review Status

					relevant zoning regulations as proposed by Planning and Zoning must be adhered to. <b>Acknowledged</b>
	ZONING	Lauren Gratzer Lauren.Gratzer@copbfl.com	pamela.mccleod@copbfl.com	AuthorizedWithConditions	<p>1. The previous site plan showed the square footage for each use of each building, however, the newest site plan does not provide these numbers. Include a plan that shows the square footage of each use. <b>Square footages shown on Sp101 Site Plan</b></p> <p>2. The front setback changed from 11'-2" to 11'-6". Update this on the site data table of the site plan. <b>Site data table updated.</b></p> <p>3. Provide call outs on the elevation for the new door on the south elevation. <b>Entry doors called out on A201 Exterior Elevations</b></p> <p>4. The new entrance and stairway on the south side of the building was not incorporated into the elevations or rendering on the cover sheet. Update these plans to reflect this change. <b>Renderings and Color elevations updated to reflect this change.</b></p> <p>5. At least 30 percent of the street-facing façade area of the ground-level floor of buildings (as measured from the grade to the underside of the eave, top of the parapet, or the story line denoting the second floor) shall be occupied by windows or doorways (155.5602.C.7). All ground-level windows on street-facing facades shall be transparent. Mirrored or heavily-tinted glass that prevents views into the building is prohibited on street-facing front building facades. It is understood that the applicant will apply for a Vernacular or Superior Design Alternative for this comment by the AAC. If the AAC does not approve a Vernacular or Superior Design Alternative, the spandrel glazing will not be permitted on the street sides, as the windows have to be transparent.</p> <p><b>Will request exception to requirement through Superior Design Alternative with AAC</b></p> <p>6. Code section 155.5602.C.8.b requires that flat roofs on principal buildings have three-dimensional cornice treatment that project at least eight inches outward from the parapet</p>

**AAC**  
PZ21-12000001

07/06/21

## Current Project - Department Review Status

					<p>facade plane. Staff recommends that the applicant include this code section in their Vernacular or Superior Alternative Design with a second option when presented to the Architectural Appearance Committee.</p> <p><b>Will request exception to requirement through Superior Design Alternative with AAC</b></p> <p>7. Submit a ROW dedication application to the Planning and Zoning Division for the dedication of 5' along NW 12th Street before building permit approval (155.501.F.2).</p> <p><b>Acknowledged</b></p> <p>8. A sidewalk public access easement agreement is required for the 1' extension of the public sidewalk into the subject property, prior to building permit approval.</p> <p><b>Acknowledged</b></p>
	BUILDING DIVISION	James DeMars james.demars@copbfl.com	pamela.mccleod@copbfl.com	AuthorizedWithConditions	<p>Advisory Comments</p> <p>A preliminary examination of the documents has been performed; additional comments may apply when completed plans and/or specifications have been submitted for permitting to the building department. Buildings shall comply with all local, state and federal codes in effect at time of application, including FEMA Floodplain, NPDES and HVHZ regulations. <b>Acknowledged</b></p> <p>FBC_BCA 105.2.3 Public service agencies/other approvals. The building official shall require that the laws, rules and regulations of any other regulatory AHJ, and where such laws, rules and regulations are applicable and are known to the building official, shall be satisfied before a permit shall be issued. The building official shall require such evidence, as in his or her opinion is reasonable, to show such other approvals.</p> <p><b>Acknowledged</b></p> <p>City Ordinance 53.16(A)(1) Construction sites and construction activities, construction sites and operations shall be required to maintain during and after all construction, development, excavation or alteration operations, structural</p>

PZ21-12000001

07/06/21

## Current Project - Department Review Status

					<p>and non-structural best management practices with the intent to reduce pollutants and sediment in stormwater runoff.</p> <p>City Ordinance 152.06(A): If applicable, contractor shall provide temporary screened fence complying with City Ordinance 152.06(B) through 152.06(G). <b>Acknowledged</b></p> <p>FBC 3306.1 Pedestrians shall be protected during construction, remodeling and demolition activities as required by this Chapter and Table 3306.1. Signs shall be provided to direct pedestrian traffic. <b>Acknowledged</b></p> <p>City Ordinance 152.25(A) Site plans and construction documents, Information for development in areas with base flood elevations. The site plan or construction documents for any development subject to the requirements of the floodplain regulations shall be drawn to scale and shall include, as applicable to the proposed development all sections from: City Ordinance 152.25 (A)(1) thru City Ordinance 152.25 (A)(7). Delineation of flood hazard areas, floodway boundaries and flood zone(s), base flood elevation(s), and ground elevations if necessary for review of the proposed development, etc. nonresidential buildings shall comply with City Ordinance 152.29(C)(1)(B). <b>Acknowledged</b></p> <p>FHA Title VIII of the Civil Rights Act of 1968, commonly known as the Fair Housing Act, prohibits discrimination in the sale, rental, and financing of dwellings based on race, color, religion, sex, and national origin. In 1988, Congress passed the Fair Housing Amendments Act. The Amendments expand coverage of Title VIII to prohibit discriminatory housing practices based on disability and familial status. Now it is unlawful to deny the rental or sale of a dwelling unit to a person because that person has a disability. <b>Acknowledged</b></p>
--	--	--	--	--	---

AAC

PZ21-12000001

07/06/21



## Current Project - Department Review Status

					<p>FBC A201.1 This code establishes standards for accessibility to places of public accommodation and commercial facilities by individuals with disabilities. All new or altered public buildings and facilities, private buildings and facilities, places of public accommodation and commercial facilities subject to this code shall comply with 2017 FBC Accessibility. <b>Acknowledged</b></p> <p>FBC A206.2.1 Site arrival points. At least one accessible route shall be provided within the site from accessible parking spaces complying with FBC A502 and accessible passenger loading zones complying with FBC A209; public streets and sidewalks; and public transportation stops to the accessible building or facility entrance they serve. <b>Acknowledged</b></p> <p>FBC_BCA 107.3.4.0.6 Compliance with the specific minimum requirements of this code shall not be in itself deemed sufficient to assure that a building or structure complies with all of the requirements of this code. it is the responsibility of the architect and/or engineer of record for the building, structure or facility to determine through rational analysis what design requirements are necessary to comply with 2020 FBC. <b>Acknowledged</b></p> <p>1. FBC_BCA 107.1 As per the building official, separate building applications will be required for erosion control, site work, temporary fences, monumental signage and miscellaneous site structures. <b>Acknowledged</b></p> <p>2. FBC_BCA 105.9 Asbestos. The enforcing agency shall require each building permit for the demolition or renovation of an existing structure to contain an asbestos notification statement which indicates the owner's or operator's responsibility to comply with the provisions of section 469.03 Florida Statutes and to notify the department of environmental protection of his or her intentions to remove asbestos, when applicable, in accordance with</p>
--	--	--	--	--	--

## Current Project - Department Review Status

					<p>state and federal law. Contractor will be required to submit Broward County asbestos program certificate of submittal indicating that the statement of responsibility has been submitted. <b>Acknowledged</b></p> <p>3. FBC [F] 903.2 The enforcing agency will require that all provisions for an approved automatic sprinkler systems in new buildings and structures be provided in the locations described in sections 903.2.1 through 903.2.12 if applicable. <b>Acknowledged</b></p> <p>4. FBC 701.1 The enforcing agency will require that the provisions of this chapter, governing the materials, systems and assemblies used for structural fire resistance and fire-resistance-rated construction separation of adjacent spaces to safeguard against the spread of fire and smoke within a building and the spread of fire to or from buildings, comply with this section of the code. <b>Acknowledged</b></p> <p>5. FBC 703.2 Fire-resistance ratings. Where materials, systems or devices that have not been tested as part of a fire-resistance-rated assembly are incorporated into the building element, component or assembly, sufficient data shall be made available to the building official to show that the required fire-resistance rating is not reduced. Materials and methods of construction used to protect joints and penetrations in fire-resistance-rated building elements, components or assemblies shall not reduce the required fire-resistance rating. <b>Acknowledged</b></p> <p>6. FBC 1003.1 The enforcing agency will require that all general requirements specified in sections 1003 through 1013, applicable to all three elements of the means of egress system, in addition to those specific requirements for the exit access, the exit and the exit discharge, comply with this section of the code. <b>Acknowledged</b></p>
--	--	--	--	--	--

AAC

PZ21-12000001

07/06/21

## Current Project - Department Review Status

					<p>7. FBC_BCA 107.1.1 The enforcing agency will require a life safety plan illustrating the floor area with proposed alterations with each room labeled. indicate construction type, fire rated walls, occupancy type: (current and proposed), occupancy load, means of egress, common path/travel distance/dead end corridor limits, accessibility accommodations including areas of refuge if applicable, emergency lighting, exits/exit signage, fire extinguishers, smoke alarms, fire suppression system and pull stations if applicable. Also provide tested design from accepted agency for rated walls and penetration details. <b>Acknowledged</b></p> <p>8. FBC_BCA 107.3.5.6 The enforcing agency will require product approvals be reviewed and approved by the building designer prior to submittal to verify that such products comply with the design specifications. Reviewed and approved product approvals shall then become part of the plans and/or specifications. Product approval shall be filed with the building official for review and approval prior to installation. <b>Acknowledged</b></p> <p>9. FBC_BCA 107.3.5.2 The enforcing agency will require that all shop drawings, (i.e. components attached to building structure, joists, window walls, railings, awnings, ...etc), necessary to show compliance with applicable codes; shall be approved by the architect or professional engineer and submitted to the building official prior to installation. <b>Acknowledged</b></p> <p>10. F.S. 481.221(2) The enforcing agency will require digital signature panel to be active on all documents submitted for review to authenticate the serial number matches the submitted ESA. F.A.C. 61g1-16.005 Each sheet is required to be initially or electronically signed, and bear the impress seal of, an architect or engineer (FBC_BCA 107.3.4(0.1)). <b>Acknowledged</b></p>
--	--	--	--	--	--

AAC

PZ21-12000001

07/06/21

## Current Project - Department Review Status

					<p>11. FBC_BCA 107.3.4.0.8 All plans and/or specifications prepared by an architect or an engineer pursuant to the requirements of this code shall be hand signed, dated and sealed. <b>Acknowledged</b></p> <p>12. FBC_BCA 110.10.1 The enforcing agency will require a special inspector for various components of the building as determined by the building official. Building dept. will require special inspector form be completed and submitted for approval. <b>Acknowledged</b></p> <p>13. FBC 1512.3.1 The enforcing agency will require that all new roofing construction, including recovering and reroofing, repair or maintenance shall have A HVHZ uniform roofing permit application, as established by the authority having jurisdiction, completed and executed by a licensed contractor. Fbc 1512.3.2 The uniform roofing permit shall include calculations in accordance With Chapter 16 (High-Velocity Hurricane Zones) of this code, unless the roofing assembly is less than the height/pressure threshold allowed in the applicable protocols herein. <b>Acknowledged</b></p> <p>14. FBC A208.2 Minimum number. Parking spaces complying with 502 shall be provided in accordance with table 208.2 except as required by 208.2.1, 208.2.2, and 208.2.3. Where more than one parking facility is provided on a site, the number of accessible spaces provided on the site shall be calculated according to the number of spaces required for each parking facility. <b>Acknowledged</b></p> <p>15. FBC A208.2.3.3 Parking for guests, employees, and other non-residents. Where parking spaces are provided for persons other than residents, parking shall be provided in accordance with table 208.2. <b>Acknowledged</b></p> <p>16. FBC A502.6 The enforcing agency will require parking space identification comply with the following code: signs shall include the</p>
--	--	--	--	--	--

## Current Project - Department Review Status

				<p>international symbol of accessibility complying with FBC A703.7.2.1. Signs identifying van parking spaces when required By FBC A502.2 shall contain the designation "Van Accessible." Reference Engineering Standard 300-5. <b>Acknowledged</b></p> <p>17. FBC 3303.5 Water Accumulation. The enforcing agency will require provisions be made to prevent the accumulation of water or damage to any foundations on the premises or the adjoining property. <b>Acknowledged</b></p> <p>18. 1804.4 Site Grading. The ground immediately adjacent to the foundation shall be sloped away from the building at a slope of not less than one unit vertical in 20 units horizontal (5-percent slope) for a minimum distance of 10 feet measured perpendicular to the face of the wall. If physical obstructions or lot lines prohibit 10 feet of horizontal distance, a 5-percent slope shall be provided to an approved alternative method of diverting water away from the foundation. Swales used for this purpose shall be sloped a minimum of 2 percent where located within 10 feet of the building foundation. Impervious surfaces within 10 feet of the building foundation shall be sloped a minimum of 2 percent away from the building. <b>Acknowledged</b></p> <p>19. FBC_BCA 110.13.2.1 It shall be the joint responsibility of any owner of real property upon which construction is occurring, and any contractor responsible for said construction, to ensure that all road rights-of-way remain free at all times of all construction waste and trash resulting from such construction, and that all waste and trash resulting from the construction are contained on the real property upon which the construction occurs. <b>Acknowledged</b></p> <p>20. FBC_BCA 109.3 Building Permit Valuations. The applicant for a permit shall provide an estimated permit value at a time of application. Permit valuations shall include</p>
--	--	--	--	--

AAC

PZ21-12000001

07/06/21

## Current Project - Department Review Status

					<p>total value of work, including materials and labor, for which the permit is being issued, such as electrical, gas, mechanical, plumbing equipment and permanent systems.</p> <p>Acknowledged</p> <p>21. FBC_BCA 110.8.5.4 All plans for the building which are required to be signed and sealed by the architect or engineer of record contain a statement that, to the best of the architect's or engineer's knowledge, the plans and specifications comply with the applicable minimum building codes and the applicable fire-safety standards as determined by the local authority in accordance with this section and chapter 633, Florida Statutes.</p> <p>Acknowledged</p>
	PLANNING	Daniel Keester daniel.keester@copbfl.com	pamela.mccleod@copbfl.com	AuthorizedWithConditions	<p>-The property has an approved recorded plat (Monticello Park - PB 10, Pg 68) and was approved prior to 1953. Based on Broward County's Administrative Rules Document Broward Next (4.3) regarding platting exemption, it appears as though replatting would not be required for the proposed non-residential development as the property is less than 10 acres in size and the plat was recorded prior to June 4, 1953. The Applicant may want to confirm with the Broward County Planning Council by way of a platting determination letter. Acknowledged</p> <p>-Land use for this parcel is C (Commercial), the zoning is B-3 (General Business). The narrative describes the future intended uses on the property as a "Medical Office with a maximum gross floor area of 5,000 square feet" and the new "Senior Center." Please note that not all "medical offices" are permitted by right in this zoning district &amp; certain "medical offices," even if they are at or less than 5,000 square feet may have additional use-standards. The proposed use is in compliance, but must adhere to all conditions of the development order &amp; relevant zoning regulations.</p> <p>-The property is accessed from NW 12th Street and N Dixie Highway. NW 12th Street is within</p>

## Current Project - Department Review Status

					<p>a non-residential zoning district, not specifically listed in the Trafficways Plan or Code of Ordinances (100.01 Minimum right-of-way). Based on the survey submitted, only 40 feet of public right-of-way exists. Given the non-residential zoning district, the code technically require 60 feet of right-of-way (thus requiring an additional 10 feet to provide the minimum 30 feet to the centerline), only a 5 foot dedication has been noted on the site plan, which was approved by the City Engineer, given the fact the roadway leads into a residential area.</p> <p>-The property also fronts on North Dixie Highway, which is identified on the Broward County Trafficways Plan. On the Trafficways Plan, North Dixie Highway (at this location) is designated as a "Collector Road" with a minimum of 80 feet right-of-way required. The survey indicates that 40 feet of right-of-way are provided to the center line of the road, and no additional dedications are required along Dixie Highway. <b>Acknowledged</b></p> <p>-The City Commission approved a Resolution (Reso. 2014-131) in 2014 adopting a Transportation Corridor Study. A copy of the Transportation Corridor Study is posted on the city's Planning &amp; Zoning webpage. Additionally, all site plan applications must demonstrate compliance during site plan review as it is a review standard: "Complies with the approved Transportation Corridor Study, unless in direct conflict with another zoning code provision." Please review the study &amp; applicable recommendations. <b>Acknowledged</b></p> <p>-The city has sufficient capacity to accommodate the proposal.</p>
--	--	--	--	--	---

# AAC

PZ21-12000001

07/06/21