

Memo

To: Zoning Board of Appeals
From: James Galloway, Fire Inspector
Date: July 7, 2021
Re: Zoning Board of Appeal 21-11000012

Due to the fact the petitioner is able to meet all of the Fire Department requirements at this time we have no objections to the request for a Variance. However, the petitioner shall maintain all proper fire department access as per chapter 18 of NFPA 1 as amended from time to time.

*Additional comments may follow throughout the remainder of the permitting process. The building shall be in compliance with All NFPA Standards prior to receiving Fire Department approval.

CC: Pete McGinnis, Fire Marshal