



ESTIMATED WATER DEMANDS:
38.96 GPM (AVG.), 155.86 GPM [224,434 GPD] (PEAK)
ESTIMATED REQUIRED FIRE FLOW = 1,500 GPM

ESTIMATED SEWER DEMANDS:
38.96 GPM (AVG.), 155.86 GPD [224,434 GPD] (PEAK)

CAULFIELD & WHEELER, INC.
CIVIL ENGINEERING - LAND PLANNING
LANDSCAPE ARCHITECTURE - SURVEYING
7900 GLADES ROAD - SUITE 100
BOCA RATON, FLORIDA 33434
PHONE (561) 392-1991 / FAX (561) 750-4452

DATE 04/03/2023
DRAWN BY RHT
F.B./ PG. N/A
SCALE 1"=50'

JOB #10326
SHT.NO. WS.01
OF 8 SHEETS

PZ23-12000017

06-25-2025