

SPRINKLER HEAD LEGEND

SYM.	TYPE	MODEL
	POP UP ROTORS	HUNTER #PGP-ADJ-07
	6" POP UP SPRAYS	HUNTER #PROS-06-NOZZLE BELOW
	12" POP UP SPRAYS	HUNTER #PROS-12-NOZZLE BELOW
	6" SHRUB RISERS	HUNTER #PROS-06-10"ADJ
	FLOOD BUBBLERS	HUNTER #PCB-10
		#PCB-50

NOTES:
ALL HEADS TO HAVE SCREENS
RAINBIRD OR K-RAIN EQUAL SPRINKLERS MAY BE SUBSTITUTED
(DO NOT MIX IN A CATEGORY)

NOTES:

PIPING:
MAINLINE: SCH. 40 PVC X 18" DEEP
ZONELINES & DRIP HEADERS: CLASS 200 PVC
DRIPLINES: 9 X 12" AS SPECIFIED
SLEEVES: SCH. 40 PVC AS NOTED

FITTINGS:
SCH. 40 PVC. FABRICATE FITTINGS OR JOINTS AS FOLLOWS:
CLEAN, SQUARE CUT AND FULLY ENGAGE. USE PVC CLEANER
AND MEDIUM BODY GREY CEMENT FOR ALL CONNECTIONS

CONTROL WIRING:
14 AWG IRRIGATION WIRE RUN WITH MAIN OR CONDUIT WHERE REQUIRED
FOR PROTECTION. COIL 3 FT. OF WIRE AT ALL CONNECTIONS. USE DRY
WATER PROOF CONNECTORS AT ALL SPLICES. RUN 2 WIRES TO ENDS OF MAIN.

BACKFILL ALL TRENCHES FREE OF DEBRIS OR ROCKS. COMPACT
TRENCHES TO ORIGINAL DENSITY. FLUSH ALL LINES. USE PROPER
SCREENS IN ALL HEADS. SET HEADS FLUSH TO GRADE AND STRAIGHT
KEEP HEADS A MIN. 12" OFF WALLS OR PAVED AREAS. ADJUST SYSTEM
FOR COMPLETE COVERAGE AVOIDING WATER ON WALLS AND PAVEMENT.
CONTRACTOR MAY MAKE MINOR ADJUSTMENTS TO SUIT ACTUAL FIELD
CONDITIONS. ROUTE PIPING AS REQUIRED TO AVOID TREE ROOTS AND
OTHER STRUCTURES

PRESSURE TEST MAIN AT FULL CITY PRESSURE FOR 2 HOURS. OBSERVE
ANY LEAKAGE AT METER AND REPAIR AS REQUIRED.

CONTRACTOR TO VERIFY ALL UNDERGROUND UTILITIES AS REQUIRED.
BY FLORIDA LAW.

PROVIDE OWNER WITH AN "AS INSTALLED PLAN" SHOWING THE LOCATION
OF VALVES AND SLEEVES.

INSTALLATION SHALL COMPLY TO THE FLORIDA BUILDING CODE APPENDIX "F".
LATEST BROWARD COUNTY EDITION AND ALL CODES AND REGULATIONS OF
THE CITY OF POMPANO BEACH.

Control Precipitation Design, Inc.
Irrigation Consultants
P.O. Box 2268
Boca Raton, Florida 33437
Tel: (561) 391-3936 Fax: (561) 391-5310
e-mail: irrdsh@bellsouth.net

IRRIGATION PLAN PRELIMINARY SUBMITTAL

0 5' 10' 20'
SCALE: 1" = 10'




AUTOMOTIVE CUSTOMIZERS WAREHOUSE
1359 N.W. 17th PLACE, POMPANO BEACH, FLORIDA

REVISIONS

NO.	DESCRIPTION

DRAWN BY:
R.J.H.



09-12-25

#23106

IR-1

RAM DESIGN, INC. - 10001 N.W. 50TH ST., SUITE 2036, SUNRISE, FLORIDA 33351 (954) 748-5661 FAX: 747-09-09
FLORIDA DEPT. OF PROFESSIONAL REGULATION
BOARD OF ARCHITECTURE LICENSE #0009409