



Legislation Details (With Text)

File #: LN-483 **Version:** 3 **Name:**

Type: DRC Submission **Status:** Passed

File created: 6/29/2023 **In control:** Development Review Committee

On agenda: 11/15/2023 **Final action:** 11/15/2023

Title: CHICK-FIL-A POMPANO BEACH

Sponsors:

Indexes:

Code sections:

Attachments: 1. DRC Documents_07.19.2023.zip, 2. DRC Drawings_07.19.2023.zip, 3. DRC Documents_09.20.2023.zip, 4. DRC Drawings_09.20.2023.zip, 5. DRC Documents_11.15.2023.zip, 6. DRC Drawings_11.15.2023.zip

Date	Ver.	Action By	Action	Result
11/15/2023	3	Development Review Committee	APPROVED WITH CONDITIONS	
9/20/2023	1	Development Review Committee	RESUBMITTAL REQUIRED	

DEVELOPMENT REVIEW COMMITTEE
Meeting Date: NOVEMBER 15, 2023

CHICK-FIL-A POMPANO BEACH

Request: Minor Site Plan
P&Z# 23-12000022
Owner: The David R Wellens Revocable trust U/A 06/01/05
Project Location: 2250 N Federal Hwy
Folio Number: 484330450010
Land Use Designation: C (Commercial)
Zoning District: B-3 (General Business)
Commission District: 1 (Andrea McGee)
Agent: Jenny Baez (954-884-5259 / jbaez@bowman.com)
Project Planner: Hellena Lahens (954-786-5554 / hellena.lahens@copbfl.com)

Summary:

The Applicant is requesting to build an addition of 340 sf to the existing restaurant.

Staff Conditions:

PLANNING

Plan Reviewer: Max Wemyss (max.wemyss@copbfl.com)
 Status: Review Complete Pending Development Order

-Land use for this parcel is Commercial (C). The proposed use listed on the site plan, site data & narrative

describe this as an addition/expansion to the kitchen storage. The total size of the proposed structure is approximately 4251 square feet (375 square feet addition) which is a permitted use in this land use category.

- The property is platted (Wellens Family Trust Property Pompano - ORB 178 Pg 150), and was later amended by Instrument #118349998. The amended plat note restricts the property to 6,000 square feet of commercial use.
- The property is abuts Federal Highway (AKA: US-1). The plat indicates that there is a minimum of 120 feet of right-of-way, and 60 feet to the centerline that was dedicated by plat. In chapter 100 (Streets and sidewalks), the code requires that the minimum right-of-way width for this roadway is 120 feet. Thus no additional dedication for future right-of-way is required.

LANDSCAPE REVIEW

Plan Reviewer: Wade Collum (wade.collum@copbfl.com)
Status: Review Complete Pending Development Order

No comments.

ZONING

Plan Reviewer: Hellena Lahens (Hellena.lahens@copbfl.com)
Status: Review Complete Pending Development Order

No objection. Zoning comments have been addressed. Upon receipt of the development order, upload document to the associated building permit.

FIRE DEPARTMENT

Plan Reviewer: Jim Galloway (jim.galloway@copbfl.com)
Status: Review Complete Pending Development Order

This P&Z application is able to meet all of the Fire Department requirements at this time for Site Plan Review. However, the petitioner shall maintain all proper fire department access and water supply requirements as per chapter 18 of NFPA 1 as amended from time to time.

*Additional comments may follow throughout the remainder of the permitting process. The buildings shall be in compliance with All NFPA Standards prior to receiving Fire Department approval.

ENGINEERING DEPARTMENT

Plan Reviewer: David McGirr (david.mcgirr@copbfl.com)
Status: Review Complete Pending Development Order

Please provide a sedimentation and erosion control plan for the proposed on-site work.

CRA

Plan Reviewer: Kimberly Vazquez (kimberly.vazquez@copbfl.com)

Status:

No comments rendered at this time.

UTILITIES

Plan Reviewer: Nathaniel Watson (nathaniel.watson@copbfl.com)

Status: Review Complete Pending Development Order

1. Please note that additional comments may be forthcoming contingent upon future submittals to the PAM and/or DRC review process.
2. Please procure an approved Broward County EPD Surface Water Management permit or exemption for the proposed site and off-site work. Required during official e-plan submittal.
3. Please provide a sedimentation and erosion control plan for the proposed on-site work.

ENVIRONMENTAL SERVICES

Plan Reviewer: Beth Dubow (beth.dubow@copbfl.com)

Status: Review Complete Pending Development Order

NOTE: Recycling collection is not required, but it is highly encouraged. Recycling collection service may be obtained from a recovered materials hauler.

NOTE: Owners of a commercial property are responsible for securing garbage collection service directly from Coastal Waste & Recycling (as of October 1, 2022).

NOTE: As stated in the Pompano Beach Code of Ordinances, Chapter 96, including Section 96.12(D)(1), all construction and demolition debris removal is the responsibility of the owner. All solid waste generated within the geographic boundaries of Pompano Beach shall be collected by the franchise collector (Coastal Waste & Recycling at the time of this writing) and disposed of as directed by the city disposal agreement. All materials shall be generated from the property on which the materials are placed for removal. Information regarding container size and hauling costs may be found in Chapter 96, Section 96.13.

NOTE: Additional comments may be necessary based upon revisions, additional plans and/or documents. Contact Beth Dubow at 954-545-7047 or beth.dubow@copbfl.com should you have any questions or concerns regarding this review.

BUILDING DIVISION

Plan Reviewer: Todd Stricker (todd.stricker@copbfl.com)

Status: Review Complete Pending Development Order

Advisory Comments

A preliminary examination of the documents has been performed; additional comments may apply when completed plans and/or specifications have been submitted for permitting to the building department. Buildings shall comply with all local, state and federal codes in effect at time of application, including FEMA Floodplain, NPDES and HVHZ regulations.

FBC_BCA 105.2.3 Public service agencies/other approvals. The building official shall require that the laws, rules and regulations of any other regulatory AHJ, and where such laws, rules and regulations are applicable and are known to the building official, shall be satisfied before a permit shall be issued. The building official shall require such evidence, as in his or her opinion is reasonable, to show such other approvals.

City Ordinance 53.16(A)(1) Construction sites and construction activities. construction sites and operations shall be required to maintain during and after all construction, development excavation or alteration operations, structural and non-structural best management practices with the intent to reduce pollutants and sediment in stormwater runoff.

City Ordinance 152.06(A): If applicable, contractor shall provide temporary screened fence complying with City Ordinance 152.06(B) through 152.06(G).

FBC 3306.1 Pedestrians shall be protected during construction, remodeling and demolition activities as required by this Chapter and Table 3306.1. Signs shall be provided to direct pedestrian traffic.

City Ordinance 152.25(A) Site plans and construction documents, Information for development in areas

FBC A201.1 This code establishes standards for accessibility to places of public accommodation and commercial facilities by individuals with disabilities. All new or altered public buildings and facilities, private buildings and facilities, places of public accommodation and commercial facilities subject to this code shall comply with 2020 FBC Accessibility.

FBC A206.2.1 Site arrival points. At least one accessible route shall be provided within the site from accessible parking spaces complying with FBC A502 and accessible passenger loading zones complying with FBC A209; public streets and sidewalks; and public transportation stops to the accessible building or facility entrance they serve.

FBC_BCA 107.3.4.0.6 Compliance with the specific minimum requirements of this code shall not be in itself deemed sufficient to assure that a building or structure complies with all of the requirements of this code. it is the responsibility of the architect and/or engineer of record for the building, structure or facility to determine through rational analysis what design requirements are necessary to comply with 2020 FBC.

1. FBC_BCA 107.1 As per the building official, separate building applications will be required for erosion control, site work, temporary fences, monumental signage and miscellaneous site structures.
2. F.S. 481.221(2) The enforcing agency will require digital signature panel to be active on all documents submitted for review to authenticate the serial number matches the submitted ESA. F.A.C. 61g1-16.005 Each sheet is required to be digitally or electronically signed, and bear the impress seal of, an architect or engineer

(FBC_BCA 107.3.4.0.1).

3. FBC_BCA 107.3.4.0.8 All plans and/or specifications prepared by an architect or an engineer pursuant to the requirements of this code shall be hand signed, dated and sealed.

4. FBC A208.2 Minimum number. Parking spaces complying with 502 shall be provided in accordance with table 208.2 except as required by 208.2.1, 208.2.2, and 208.2.3. Where more than one parking facility is provided on a site, the number of accessible spaces provided on the site shall be calculated according to the number of spaces required for each parking facility.

5. FBC A208.2.3.3 Parking for guests, employees, and other non-residents. Where parking spaces are provided for persons other than residents, parking shall be provided in accordance with table 208.2.

6. FBC A502.6 The enforcing agency will require parking space identification comply with the following code: signs shall include the international symbol of accessibility complying with FBC A703.7.2.1. Signs identifying van parking spaces when required By FBC A502.2 shall contain the designation "Van Accessible." Reference Engineering Standard 300-5.

7. FBC 3303.5 Water Accumulation. The enforcing agency will require provisions be made to prevent the accumulation of water or damage to any foundations on the premises or the adjoining property.

8. 1804.4 Site Grading. The ground immediately adjacent to the foundation shall be sloped away from the building at a slope of not less than one unit vertical in 20 units horizontal (5-percent slope) for a minimum distance of 10 feet measured perpendicular to the face of the wall. If physical obstructions or lot lines prohibit 10 feet of horizontal distance, a 5-percent slope shall be provided to an approved alternative method of diverting water away from the foundation. Swales used for this purpose shall be sloped a minimum of 2 percent where located within 10 feet of the building foundation. Impervious surfaces within 10 feet of the building foundation shall be sloped a minimum of 2 percent away from the building.

9. FBC_BCA 110.13.2.1 It shall be the joint responsibility of any owner of real property upon which construction is occurring, and any contractor responsible for said construction, to ensure that all road rights-of-way remain free at all times of all construction waste and trash resulting from such construction, and that all waste and trash resulting from the construction are contained on the real property upon which the construction occurs.

10. FBC_BCA 109.3 Building Permit Valuations. The applicant for a permit shall provide an estimated permit value at a time of application. Permit valuations, shall include total value of work, including materials and labor, for which the permit is being issued, such as electrical, gas, mechanical, plumbing equipment and permanent systems.

11. FBC_BCA 110.8.5.4 All plans for the building which are required to be signed and sealed by the architect or engineer of record contain a statement that, to the best of the architect's or engineer's knowledge, the plans and specifications comply with the applicable minimum building codes and the applicable fire-safety standards as determined by the local authority in accordance with this section and chapter 633, Florida Statutes.

BSO

Plan Reviewer: Anthony Russo (Anthony_russo@sheriff.org)
Status: Review Complete Pending Development Order

*** ATTENTION IMPORTANT ***

The services of an independent, and highly experienced, qualified and certified Security Crime Prevention/ CPTED Consultant are highly recommended to achieve and maintain objective credible security review integrity, and to expedite processing.

*** DISCLAIMER ***

This safety and security review does not guarantee a crime will never occur; it is an effort to mitigate opportunities for crime and to help avoid any present and future security deficiencies, conflicts, threats, breaches, or liabilities that might occur without any review.

*** ATTENTION IMPORTANT ***

AS PER CODE 155.2407.E.9., AT THE TIME OF PERMIT SUBMITTAL, THE CPTED SECURITY STRENGTHENING DRAWING PLAN AND SEPARATE CPTED SECURITY STRENGTHENING DRAWING PLAN NARRATIVE SHALL BOTH BE SUBMITTED AS PART OF THE REQUIREMENTS FOR PLANNING & ZONING REVIEW AND APPROVAL.

ATTENTION IMPORTANT

Participation in the BSO No Trespassing Program is required. If this site is already on the program, then additional signage may be necessary along with an updated affidavit signed by authorized personnel. Please contact the BSO Pompano Beach C.P.T.E.D Advisor regarding placement of the No Trespass Signs.

*** ATTENTION IMPORTANT ***

PROPOSED CAMERA AND MONITORING LOCATIONS WILL BE COORDINATED WITH A SECURITY AND ACCESS CONTROL CONSULTANT AND THE BROWARD SHERIFF'S OFFICE CPTED REVIEWER *** PRIOR *** TO PERMITTING. PLANNING AND INSTALLATION OF THE SURVEILLANCE MONITORING SYSTEM MUST INCLUDE FIELD INPUT FROM EXPERIENCED CPTED/ SECURITY STRENGTHENING LAW-ENFORCEMENT TO ENSURE OPTIMAL RESULTS.

PLEASE NOTE: Applications that require resubmission to the DRC have 45 days from the time of original DRC meeting in which to resubmit. Applications that fail to be resubmitted before the completion of these 45 days, or fail to receive a time extension from the Development Services Director, shall be considered withdrawn (§155.2304.B).