



# Legislation Details (With Text)

File #: LN-490 Version: 3 Name:

Type: DRC Submission Status: Passed

File created: 6/29/2023 In control: Development Review Committee

On agenda: 12/20/2023 Final action: 12/20/2023

Title: BLP POMPANO BEACH - TRUCK COURT

Sponsors:

Indexes:

Code sections:

Attachments: 1. DRC Drawings\_07.19.2023.zip, 2. DRC Documents\_07.19.2023.zip, 3. DRC

Drawings 09.06.2023.zip, 4. DRC Documents 09.06.2023.zip, 5. DRC Documents 12.20.2023.zip,

6. DRC Drawings\_12.20.2023.zip

Date	Ver.	Action By	Action	Result
12/20/2023	3	Development Review Committee	APPROVED WITH CONDITIONS	
12/20/2023	3	Development Review Committee	APPROVED WITH CONDITIONS	
9/6/2023	2	Development Review Committee	APPROVED WITH CONDITIONS	

DEVELOPMENT REVIEW COMMITTEE

Meeting Date: DECEMBER 20, 2023

## **BLP POMPANO BEACH - TRUCK COURT**

**Request:** Minor Site Plan **P&Z#** 23-12000018

Owner: BLUSV I FL 290 SW 14th Avenue LLC

**Project Location:** 290 SW 14<sup>th</sup> Avenue

**Folio Number:** 494203000036, 494203000038 & 494203000043

**Land Use Designation:** I (Industrial)

**Zoning District:** I-1 (General Industrial)

**Commission District:** 5 (Barry Moss)

Agent: Noah Martin (985-201-4744 / nmartin@langan.com)

**Project Planner:** Hellena Lahens (954-786-5554 / hellena.lahens@copbfl.com)

## **Summary:**

The applicant is requesting to construct a truck court to the rear of the existing building with site improvements for stormwater retention.

## **Staff Conditions:**

## **PLANNING**

Plan Reviewer: Max Wemyss (max.wemyss@copbfl.com Status: Review Complete Pending Development Order

Notes / No Action Necessary:

- -Land use for this parcel is Industrial, the zoning is I-1 (General Industrial). Warehouses & offices (as noted on the site plan) are listed as permitted uses in this zoning district.
- -The property appears to be unplatted; however, platting would not appear to be required for the proposed development (expansion of the asphalt truck parking/loading area.
- -Broward County Trafficways Plan requires a minimum of 106 feet on Racetrack Road (SW 3 Street); the civil plan (C-300) has been updated to identify a future right-of-way dedication of 13 feet along SW 3 Street (to be dedicated in the future, but not required with this application).
- -The property abuts SW 13 Avenue & SW 14 Avenue. The survey indicates that there is an existing 30 feet of right-of-way measured to the centerline of the road on SW 14 Avenue and 35 feet of right-of-way measured to the centerline of the road on SW 13 Avenue. The requirement in Chapter 100 indicates that these streets must provide a minimum width of 60 feet in nonresidential zoning district, which is existing & no additional action is required by the Applicant.
- -The city has sufficient wastewater treatment capacity to accommodate the proposal.

### **ZONING**

Plan Reviewer: Hellena Lahens (hellena.lahens@copbfl.com) Status: Review Complete Pending Development Order

1. Applicant must obtain a Unity of Title prior to building permit approval.

#### LANDSCAPE REVIEW

Plan Reviewer: Wade Collum (<u>wade.collum@copbfl.com</u>) Status: Review Complete Pending Development Order

- 1. Show sod to be St. Augustine on the plant list
- 2. All tree work will require permitting by a registered Broward County Tree Trimmer.
- 3. Provide a comment response sheet as to specifically how comments have been addressed at time of resubmittal.
- 4. Additional comments may be rendered a time of resubmittal.

#### FIRE DEPARTMENT

Plan Reviewer: Jim Galloway (jim.galloway@copbfl.com) Status: Review Complete Pending Development Order

This P&Z application is able to meet all of the Fire Department requirements at this time for Site Plan Review. However, the petitioner shall maintain all proper fire department access and water supply requirements as per chapter 18 of NFPA 1 as amended from time to time.

\*Additional comments may follow throughout the remainder of the permitting process. The buildings shall be in compliance with All NFPA Standards prior to receiving Fire Department approval.

## ENGINEERING DEPARTMENT

Plan Reviewer: David McGirr (<u>david.mcgirr@copbfl.com</u> Status: Review Complete Pending Development Order

The following comments must be addressed prior to the submission of these plans to the Building Division for formal plan review and permitting:

- 1.Submit / upload the (BCEPMGD) Broward County Environmental Protection and Growth Management Division Surface Water Management permit or exemption for the proposed paving and drainage shown on the civil engineering drawings
- 2. Prior to the approval of the City Engineering division, the City's Planning and Zoning Division must approve these plans.
- 3. Submit / upload the (FDEP) Florida Department of Environmental Protection (NOI) Notice of Intent for the proposed storm water discharge from the proposed site construction activities.

PLEASE PROVIDE A NARRATIVE RESPONSE TO THESE REVIEW COMMENTS (IF APPLICABLE), SEE MARKUPS (IF REFERENCED) AND CLEARLY SHOW CHANGES ON PLANS USING CLOUDED DETAILS AND DELTA REVISION MARKS AS NECESSARY.

\*\*\*\* Please note - additional review comments may be issued by the City Engineering Division throughout the remainder of the permitting process while the civil engineering plans are being finalized for this project. \*\*\*\*

#### **CRA**

Plan Reviewer: Kimberly Vazquez (<u>kimberly.vazquez@copbfl.com</u>)

Status: Review Complete Pending Development Order

This property is not in the CRA district therefore we have no comment on this project.

#### UTILITIES

Plan Reviewer: Nathaniel Watson (nathaniel.watson@copbfl.com)

Status: Review Complete Pending Development Order

- 1. Please note that additional comments may be forth coming contingent upon future submittals to the PAM and/or DRC review process.
- 2. Please procure an approved Broward County EPD Surface Water Management permit or exemption for the proposed site and off-site work. Required during official Bldg. e-plan submittal.
- 3. Please attach the following 2022 City Engineering Standard details as they apply: 101-1 Sample Point (Hydrant), 102-1 Valve Box Settings, 103-1 Gate or Valve Plug Settings, 106-1 Backflow Preventer, 107-2 Typical 2" Water Service, 115-1 Underground Valve Identification Marker, 315-1 Typical Screen For Utilities. Condition of Development Order.

#### **ENVIRONMENTAL SERVICES**

Plan Reviewer: Beth Dubow (beth.dubow@copbfl.com) Status: Review Complete Pending Development Order

1. This is an existing site with existing garbage container and enclosure. Ensure a garbage truck has access to and from the trash enclosure without backing out into the right-of-way.

NOTE: Owners of this commercial property are responsible for securing garbage collection service directly from Coastal Waste and Recycling, Inc., the City's approved garbage franchise.

NOTE: Recycling collection is not required, but it is encouraged. Recycling collection service may be obtained from a recovered materials hauler.

NOTE: As stated in the Pompano Beach Code of Ordinances, Chapter 96, including Section 96.12(D)(1), all construction and demolition debris removal is the responsibility of the owner. All solid waste generated within the geographic boundaries of Pompano Beach shall be collected by the franchise collector (Coastal Waste and Recycling at the time of this writing) and disposed of as directed by the city disposal agreement. All materials shall be generated from the property on which the materials are placed for removal. Information regarding container size and hauling costs may be found in Chapter 96, Section 96.13.

NOTE: Additional comments may be necessary based upon revisions, additional plans and/or documents. Contact Beth Dubow at 954-545-7047 or beth.dubow@copbfl.com should you have any questions or concerns regarding this review.

## **BUILDING DIVISION**

Plan Reviewer: Todd Stricker (<u>todd.stricker@copbfl.com</u>) Status: Review Complete Pending Development Order

## **Advisory Comments**

A preliminary examination of the documents has been performed; additional comments may apply when completed plans and/or specifications have been submitted for permitting to the building department. Buildings shall comply with all local, state and federal codes in effect at time of application, including FEMA Floodplain, NPDES and HVHZ regulations.

FBC\_BCA 105.2.3 Public service agencies/other approvals. The building official shall require that the laws, rules and regulations of any other regulatory AHJ, and where such laws, rules and regulations are applicable and are known to the building official, shall be satisfied before a permit shall be issued. The building official shall require such evidence, as in his or her opinion is reasonable, to show such other approvals.

City Ordinance 53.16(A)(1) Construction sites and construction activities. construction sites and operations shall be required to maintain during and after all construction, development excavation or alteration operations, structural and non-structural best management practices with the intent to reduce pollutants and sediment in stormwater runoff.

City Ordinance 152.06(A): If applicable, contractor shall provide temporary screened fence complying with City Ordinance 152.06(B) through 152.06(G).

FBC 3306.1 Pedestrians shall be protected during construction, remodeling and demolition activities as required by this Chapter and Table 3306.1. Signs shall be provided to direct pedestrian traffic.

City Ordinance 152.25(A) Site plans and construction documents, Information for development in areas with base flood elevations. The site plan or construction documents for any development subject to the requirements of the floodplain regulations shall be drawn to scale and shall include, as applicable to the proposed development all sections from: City Ordinance 152.25 (A)(1) thru City Ordinance 152.25 (A)(7). Delineation of flood hazard areas, floodway boundaries and flood zone(s), base flood elevation(s), and ground elevations if necessary for review of the proposed development, etc. nonresidential buildings shall comply with City Ordinance 152.29(C)(1)(B).

FBC A201.1 This code establishes standards for accessibility to places of public accommodation and commercial facilities by individuals with disabilities. All new or altered public buildings and facilities, private buildings and facilities, places of public accommodation and commercial facilities subject to this code shall comply with 2017 FBC Accessibility.

FBC A206.2.1 Site arrival points. At least one accessible route shall be provided within the site from accessible parking spaces complying with FBC A502 and accessible passenger loading zones complying with FBC A209; public streets and sidewalks; and public transportation stops to the accessible building or facility entrance they serve.

FBC\_BCA 107.3.4.0.6 Compliance with the specific minimum requirements of this code shall not be in itself deemed sufficient to assure that a building or structure complies with all of the requirements of this code. it is the responsibility of the architect and/or engineer of record for the building, structure or facility to determine through rational analysis what design requirements are necessary to comply with 2017 FBC.

- 1. FBC\_BCA 107.1 As per the building official, separate building applications will be required for erosion control, site work, temporary fences, monumental signage and miscellaneous site structures.
- 2. F.S. 481.221(2) The enforcing agency will require digital signature panel to be active on all documents submitted for review to authenticate the serial number matches the submitted ESA. F.A.C. 61g1-16.005 Each sheet is required to be digitally or electronically signed, and bear the impress seal of, an architect or engineer

(FBC BCA 107.3.4.0.1).

- 3. FBC\_BCA 107.3.4.0.8 All plans and/or specifications prepared by an architect or an engineer pursuant to the requirements of this code shall be hand signed, dated and sealed.
- 4. FBC A208.2 Minimum number. Parking spaces complying with 502 shall be provided in accordance with table 208.2 except as required by 208.2.1, 208.2.2, and 208.2.3. Where more than one parking facility is provided on a site, the number of accessible spaces provided on the site shall be calculated according to the number of spaces required for each parking facility.
- 5. FBC A208.2.3.3 Parking for guests, employees, and other non-residents. Where parking spaces are provided for persons other than residents, parking shall be provided in accordance with table 208.2.
- 6. FBC A502.6 The enforcing agency will require parking space identification comply with the following code: signs shall include the international symbol of accessibility complying with FBC A703.7.2.1. Signs identifying van parking spaces when required By FBC A502.2 shall contain the designation "Van Accessible." Reference Engineering Standard 300-5.
- 7. FBC\_BCA 110.13.2.1 It shall be the joint responsibility of any owner of real property upon which construction is occurring, and any contractor responsible for said construction, to ensure that all road rights-of-way remain free at all times of all construction waste and trash resulting from such construction, and that all waste and trash resulting from the construction are contained on the real property upon which the construction occurs.
- 8. FBC\_BCA 109.3 Building Permit Valuations. The applicant for a permit shall provide an estimated permit value at a time of application. Permit valuations, shall include total value of work, including materials and labor, for which the permit is being issued, such as electrical, gas, mechanical, plumbing equipment and permanent systems.
- 9. FBC\_BCA 110.8.5.4 All plans for the building which are required to be signed and sealed by the architect or engineer of record contain a statement that, to the best of the architect's or engineer's knowledge, the plans and specifications comply with the applicable minimum building codes and the applicable fire-safety standards as determined by the local authority in accordance with this section and chapter 633, Florida Statutes.

## **BSO**

Plan Reviewer: Anthony Russo (anthony\_russo@sheriff.org)

Status: Review Complete Pending Development Order

## \*\*\* ATTENTION IMPORTANT \*\*\*

The services of an independent, and highly experienced, qualified and certified Security Crime Prevention/CPTED Consultant are highly recommended to achieve and maintain objective credible security review integrity, and to expedite processing.

## \*\*\* DISCLAIMER \*\*\*

This safety and security review does not guarantee a crime will never occur; it is an effort to mitigate opportunities for crime and to help avoid any present and future security deficiencies, conflicts, threats, breaches, or liabilities that might occur without any review.

## \*\*\* ATTENTION IMPORTANT \*\*\*

AS PER CODE 155.2407.E.9., AT THE TIME OF PERMIT SUBMITTAL, THE CPTED SECURITY STRENGTHENING DRAWING PLAN AND SEPARATE CPTED SECURITY STRENGTHENING DRAWING PLAN NARRATIVE SHALL BOTH BE SUBMITTED AS PART OF THE REQUIREMENTS FOR PLANNING & ZONING REVIEW AND APPROVAL.

## \*\*\*ATTENTION IMPORTANT\*\*\*

Participation in the BSO No Trespassing Program is required. If this site is already on the program, then additional signage may be necessary along with an updated affidavit signed by authorized personnel. Please contact the BSO Pompano Beach C.P.T.E.D Advisor regarding placement of the No Trespass Signs.

PLEASE NOTE: Applications that require resubmission to the DRC have 45 days from the time of original DRC meeting in which to resubmit. Applications that fail to be resubmitted before the completion of these 45 days, or fail to receive a time extension from the Development Services Director, shall be considered withdrawn (§155.2304.B).